


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Wewak Street School (5653)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Albury</b>

5653 - Wewak Street School  
Site Plan (10856)



1:1,941

Printed: 21-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Entry Vestibule - (18.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (22.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview - (18.98 SQM)	Office (4)	
B00A - R0012 - Duplicating Workroom - (9.21 SQM)	Office (2)	
B00A - R0013 - Staff Room Annexe - (9.17 SQM)	Office (2)	
B00A - R0017 - Duplicating Workroom - (12.81 SQM)	Office (3)	
B00A - R0018 - Clerical Office - (26.23 SQM)	Office (6)	
B00B - R0001 - Movement - (31.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Hydrotherapy - Pool - (13.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Kitchen - Type 1 - (50.87 SQM)	Student Space (23)	
B00B - R0014 - Movement - (10.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Communal Space - (142.99 SQM)	Student Space (66)	
B00B - R0031 - Raised Platform - (34.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Movement - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Staff Room Annexe - (8.1 SQM)	Office (2)	
B00B - R0035 - Staff Room Annexe - (16.57 SQM)	Office (4)	
B00C - R0001 - Movement - (52.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - P - 1hb - (15.14 SQM)	Student Space (7)	
B00C - R0003 - Home Base - P - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - P - (48.9 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0006 - Practical Activities - P - 1hb - (14.95 SQM)	Student Space (6)	
B00C - R0008 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Practical Activities - P - 1hb - (15.05 SQM)	Student Space (6)	
B00D - R0007 - Home Base - P - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0008 - Home Base - P - (53.27 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0009 - Practical Activities - P - 1hb - (14.53 SQM)	Student Space (6)	
B00D - R0022 - Practical Activities - (83.19 SQM)	Student Space (38)	
B00L - R0003 - Home Base - M - (75.26 SQM) - Teaching Space: 1	Student Space (34)	
B00L - R0004 - Breakout Area - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Practical Activities - M - 2hb - (38.07 SQM)	Student Space (17)	
B00L - R0009 - Breakout Area - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Home Base - M - (75.08 SQM) - Teaching Space: 1	Student Space (34)	
B00L - R0013 - Home Base - M - (75.32 SQM) - Teaching Space: 1	Student Space (34)	
B00L - R0014 - Practical Activities - M - 2hb - (38.18 SQM)	Student Space (17)	
B00L - R0016 - Breakout Area - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Breakout Area - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Home Base - M - (74.99 SQM) - Teaching Space: 1	Student Space (34)	
B00L - R0022 - Staff Room - (51.17 SQM)	Office (12)	
B00L - R0023 - Staff Room Annexe - (25.02 SQM)	Office (6)	
B00L - R0029 - Staff Kitchen - (8.39 SQM)	Office (2)	
B00M - R0001 - Home Base - M - (75.05 SQM) - Teaching Space: 1	Student Space (34)	
B00M - R0004 - Breakout Area - (12.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0005 - Practical Activities - M - 1hb - (37.84 SQM)	Student Space (17)	
B00M - R0009 - Breakout Area - (12.6 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Reading Area - (91.41 SQM)	Student Space (42)	
B00M - R0014 - Special Programs Room - (30.89 SQM)	Student Space (14)	
B00M - R0015 - Home Base - M - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0016 - Staff Kitchen - (34.51 SQM)	Office (8)	

