

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Whalan Public School (4378)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Londonderry</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

4378 - Whalan Public School  
Site Plan (13202)


















1:950

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0005 - Home Base - (58.07 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0010 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0011 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0021 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0022 - Home Base - (86.11 SQM) - Teaching Space: 1	Student Space (39)	
B001 - R0029 - Home Base - (86.39 SQM) - Teaching Space: 1	Student Space (40)	
B001 - R0030 - Home Base - (57.35 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0035 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B001 - R0036 - Home Base - (85.99 SQM) - Teaching Space: 1	Student Space (39)	
B001 - R0043 - Withdrawal Space - 1hb - (27.9 SQM)	Student Space (12)	
B001 - R0064 - Staff Kitchen - (6.03 SQM)	Office (1)	
B001 - R0065 - Reading Area - (172 SQM)	Student Space (79)	
B002 - R0001 - Staff Study - (57.12 SQM)	Office (14)	
B002 - R0003 - Movement - (11.45 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Deputy Principal - (12.89 SQM)	Office (3)	
B002 - R0008 - Principal - (19.86 SQM)	Office (4)	
B002 - R0009 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B002 - R0010 - Sick Bay - (9.4 SQM)	Student Space (4)	
B002 - R0011 - Interview - (12.78 SQM)	Office (3)	
B002 - R0012 - Clerical Office/Workroom - (10.52 SQM)	Office (2)	
B002 - R0014 - Movement - (19.25 SQM)	Not Applicable	Circulation or storage space.
B002 - R0015 - Entry Vestibule - (12.25 SQM)	Not Applicable	Circulation or storage space.
B002 - R0016 - Clerical Office - (44.2 SQM)	Office (11)	
B002 - R0018 - Staff Room - (76.88 SQM)	Office (19)	
B002 - R0019 - Staff Room - (99.26 SQM)	Office (24)	
B002 - R0027 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B002 - R0031 - Home Base - (57.74 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0034 - Home Base - (57.34 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R0038 - Movement - (8.45 SQM)	Not Applicable	Circulation or storage space.
B002 - R0045 - Movement - (190.12 SQM)	Not Applicable	Circulation or storage space.
B002 - R1001 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R1003 - Staff Room Annexe - (29.19 SQM)	Office (7)	
B002 - R1004 - Staff Room Annexe - (15.38 SQM)	Office (3)	
B002 - R1005 - Interview - (10.87 SQM)	Office (2)	
B002 - R1009 - Movement - (213.7 SQM)	Not Applicable	Circulation or storage space.
B002 - R1010 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R1012 - Movement - (8.36 SQM)	Not Applicable	Circulation or storage space.
B002 - R1015 - Home Base - (55.45 SQM) - Teaching Space: 1	Student Space (25)	
B002 - R1016 - Home Base - (55.45 SQM) - Teaching Space: 1	Student Space (25)	
B002 - R1020 - Movement - (8.38 SQM)	Not Applicable	Circulation or storage space.
B002 - R1026 - Home Base - (67.41 SQM) - Teaching Space: 1	Student Space (31)	
B002 - R1028 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B002 - R1031 - Movement - (8.34 SQM)	Not Applicable	Circulation or storage space.
B002 - R1033 - Home Base - (55.45 SQM) - Teaching Space: 1	Student Space (25)	
B002 - R1034 - Home Base - (55.45 SQM) - Teaching Space: 1	Student Space (25)	
B002 - R1037 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B003 - R0019 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
B003 - R0027 - Movement - (26.33 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B003 - R0028 - Communal Space - (171.29 SQM)	 Student Space (79)	
B003 - R0030 - Raised Platform - (32.52 SQM)	Not Applicable	Circulation or storage space.
B003 - R0032 - Home Base - (82.21 SQM) - Teaching Space: 1	 Student Space (38)	
B003 - R1002 - Movement - (166.12 SQM)	Not Applicable	Circulation or storage space.
B003 - R1005 - Home Base - (56.64 SQM) - Teaching Space: 1	 Student Space (26)	
B003 - R1006 - Home Base - (56.64 SQM) - Teaching Space: 1	 Student Space (26)	
B003 - R1009 - Movement - (13.59 SQM)	Not Applicable	Circulation or storage space.
B003 - R1011 - Home Base - (56.73 SQM) - Teaching Space: 1	 Student Space (26)	
B003 - R1012 - Home Base - (56.57 SQM) - Teaching Space: 1	 Student Space (26)	
B003 - R1015 - Home Base - (56.72 SQM) - Teaching Space: 1	 Student Space (26)	
B003 - R1020 - Home Base - (56.72 SQM) - Teaching Space: 1	 Student Space (26)	
B004 - R0001 - Canteen - (32.92 SQM)	Not Applicable	Circulation or storage space.
B004 - R0004 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B004 - R0008 - Staff Room - (20.96 SQM)	 Office (5)	
B004 - R0009 - Staff Room - (91.75 SQM)	 Office (22)	
B005 - R0003 - Withdrawal - Pre - (41.55 SQM)	 Student Space (19)	
B005 - R0004 - Staff Room Annexe - (15.75 SQM)	 Office (3)	
B006 - R0004 - Home Base - Pre - (70.2 SQM) - Teaching Space: 1	 Student Space (32)	
B006 - R0005 - Home Base - Pre - (70.1 SQM) - Teaching Space: 1	 Student Space (32)	
OS 622 15266 - OS 622 15266 - Single Learning Unit - Early Childhood - (76 SQM)	 Student Space (35)	