

VENTILATION AUDIT REPORT

SCHOOL:	Widemere Public School (4474)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Cumberland

4474 - Widemere Public School
Site Plan (11398)



1:935

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (15.49 SQM)	Student Space (7)	
B00A - R0005 - Practical Activities - 1hb - (15.41 SQM)	Student Space (7)	
B00A - R0008 - Home Base - (55.16 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0011 - Home Base - (55.21 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0012 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0015 - Home Base - (57.1 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0005 - Practical Activities - 1hb - (20.31 SQM)	Student Space (9)	
B00B - R0006 - Home Base - (86.31 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0007 - Home Base - (86.98 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0008 - Practical Activities - 1hb - (20.21 SQM)	Student Space (9)	
B00C - R0006 - Principal - (15.48 SQM)	Office (3)	
B00C - R0007 - Duplicating Workroom - (13.79 SQM)	Office (3)	
B00C - R0008 - Sick Bay - (13.87 SQM)	Student Space (6)	
B00C - R0009 - Movement - (32.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Canteen - (31.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Entry Vestibule - (16.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Clerical Office - (14.06 SQM)	Office (3)	
B00C - R0018 - Interview - (13.18 SQM)	Office (3)	
B00C - R0022 - Movement - (22.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Room - (98.38 SQM)	Office (24)	
B00D - R0003 - Movement - (13.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (63.82 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0003 - Home Base - (63.81 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0004 - Practical Activities - 1hb - (13.88 SQM)	Student Space (6)	
B00E - R0005 - Home Base - (64.5 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0006 - Movement - (32.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Home Base - (64.39 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0013 - Movement - (81.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Practical Activities - 1hb - (14.33 SQM)	Student Space (6)	
B00E - R1002 - Home Base - (63.83 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R1003 - Home Base - (64.29 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R1004 - Practical Activities - 1hb - (13.88 SQM)	Student Space (6)	
B00E - R1005 - Home Base - (64.5 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R1006 - Movement - (32.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Interview - (15 SQM)	Office (3)	
B00E - R1012 - Home Base - (64.4 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R1013 - Movement - (75.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (58.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Communal Space - (235.51 SQM)	Student Space (109)	
B00F - R0011 - Raised Platform - (41.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (13.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (60.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - Movement - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R1013 - Reading Area - (207.92 SQM)	Student Space (96)	
B00F - R1014 - Special Programs Room - (44.91 SQM)	Student Space (20)	
B00F - R1015 - Seminar/Study - (28.17 SQM)	Office (7)	