


VENTILATION AUDIT REPORT

SCHOOL:	Wideview Public School (4433)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

4433 - Wideview Public School
Site Plan (11399)










1:1,077

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (49.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Entry Vestibule - (17.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Sick Bay - (9.76 SQM)	● Student Space (4)	
B00A - R0028 - Staff Room Annexe - (20.61 SQM)	● Office (5)	
B00A - R0029 - Staff Room Annexe - (19.63 SQM)	● Office (4)	
B00A - R0030 - Staff Room - (50.56 SQM)	● Office (12)	
B00A - R0031 - Interview - (8.17 SQM)	● Office (2)	
B00A - R0032 - Duplicating Workroom - (8.17 SQM)	● Office (2)	
B00A - R0033 - Principal - (20.7 SQM)	● Office (5)	
B00A - R0034 - Clerical Office - (9.65 SQM)	● Office (2)	
B00A - R0035 - Clerical Office/Workroom - (8.03 SQM)	● Office (2)	
B00A - R0036 - Clerical Office - (23.63 SQM)	● Office (5)	
B00A - R1007 - Movement - (53.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (59.65 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1012 - Withdrawal Space - 1hb - (12 SQM)	● Student Space (5)	
B00A - R1013 - Practical Activities - (12.02 SQM)	● Student Space (5)	
B00A - R1014 - Home Base - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1015 - Practical Activities - (8.82 SQM)	● Student Space (4)	
B00A - R1016 - Withdrawal Space - 1hb - (7.85 SQM)	● Student Space (3)	
B00A - R1018 - Home Base - (55.7 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1019 - Practical Activities - (7.23 SQM)	● Student Space (3)	
B00A - R1021 - Withdrawal Space - 1hb - (8.04 SQM)	● Student Space (3)	
B00B - R0001 - Home Base - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0004 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0007 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Movement - (7.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0013 - Movement - (67.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Special Programs Room - (41.86 SQM)	● Student Space (19)	
B00B - R9002 - Practical Activities - 1hb - (55.56 SQM)	● Student Space (25)	
B00C - R0005 - Canteen - (17.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (51.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (62.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (57.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0005 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0006 - Movement - (53.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (57.04 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0007 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Movement - (49.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R9001 - Practical Activities - 1hb - (52.77 SQM)	● Student Space (24)	
B00G - R0004 - Home Base - (85.71 SQM) - Teaching Space: 1	● Student Space (39)	
B00G - R0005 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0008 - Movement - (40.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R9001 - Special Programs Room - (56.35 SQM)	 Student Space (26)	
B00H - R0001 - Withdrawal Space - 1hb - (20.22 SQM)	 Student Space (9)	
B00H - R0007 - Movement - (20.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Interview - (14.62 SQM)	 Office (3)	
B00H - R0013 - Home Base - (56.88 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0001 - Movement - (19.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Communal Space - (237.17 SQM)	 Student Space (110)	
B00L - R0005 - Raised Platform - (51.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Movement - (45.63 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Reading Area - (165.37 SQM)	 Student Space (76)	
OS 602 16634 - OS 602 16634 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	