


VENTILATION AUDIT REPORT

SCHOOL:	Wilcannia Central School (3442)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Central Darling

3442 - Wilcannia Central School
Site Plan (10970)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Clinic-Waiting - (8.3 SQM)	Office (2)	
B00A - R0006 - Movement - (26.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Duplicating Workroom - (12.28 SQM)	Office (3)	
B00A - R0013 - Interview - (12.32 SQM)	Office (3)	
B00A - R0014 - Movement - (56.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (60.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - General Learning Space - (38.94 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R0008 - General Learning Space - (44.75 SQM) - Teaching Space: 1	Student Space (20)	
B00D - R0009 - Computer Learning Space - (41.94 SQM) - Teaching Space: 1	Student Space (19)	
B00D - R0011 - Reading Area - (157.25 SQM)	Student Space (72)	
B00D - R0015 - Movement - (18.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (50.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Home Base - (63.6 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0021 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0022 - Withdrawal Space - 1hb - (10.8 SQM)	Student Space (5)	
B00D - R0023 - Movement - (20.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Home Base - (60.68 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0025 - Movement - (30.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Movement - (61.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Movement - (56.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Movement - (31.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Withdrawal Space - 1hb - (24.42 SQM)	Student Space (11)	
B00D - R1002 - Withdrawal Space - 1hb - (21.61 SQM)	Student Space (10)	
B00D - R1005 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Staff Room - (59.8 SQM)	Office (14)	
B00D - R1007 - Staff Room Annexe - (20.41 SQM)	Office (5)	
B00D - R1008 - Movement - (14.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Withdrawal Space - 1hb - (26.46 SQM)	Student Space (12)	
B00F - R0001 - Entry Vestibule - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Clerical Office/Workroom - (9.03 SQM)	Office (2)	
B00F - R0009 - Movement - (21.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Clerical Office - (11.56 SQM)	Office (2)	
B00F - R0011 - Clerical Office/Workroom - (21.02 SQM)	Office (5)	
B00F - R0012 - Principal - (17 SQM)	Office (4)	
B00F - R0013 - Interview - (11.54 SQM)	Office (2)	
B00F - R0014 - Deputy Principal - (13.62 SQM)	Office (3)	
B00G - R0006 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (24.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - Pre - (65.16 SQM)	Student Space (30)	
B00K - R0002 - Public Reception - (21.5 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Staff Room - (19.35 SQM)	Office (4)	
B00K - R0009 - Practical Activities - Pre - (90.78 SQM)	Student Space (42)	
BOB1 - R0004 - Movement - (10.79 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0015 - Movement - (62.13 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0017 - Multi-Purpose Space - (351 SQM)	Student Space (162)	
BOB1 - R0020 - Movement - (11.37 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0022 - Raised Platform - (58.7 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0024 - Movement - (89.73 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0025 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0B1 - R0026 - Movement - (5.34 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0027 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0028 - Movement - (34.13 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0001 - Canteen - (44 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0007 - Movement - (26.24 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R0001 - Laboratory L.S. - (81.02 SQM) - Teaching Space: 1	● Student Space (37)	
B0C1 - R0002 - Preparation - (20.6 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R0005 - Preparation - Materials - (19.99 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R0006 - Food Technology L.S. - (65.8 SQM) - Teaching Space: 1	● Student Space (30)	
B0C1 - R0007 - Movement - (44.79 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R0003 - Preparation - Materials - (15.38 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R0005 - Materials Technology L.S. - (113.14 SQM) - Teaching Space: 1	● Student Space (52)	
B0C2 - R0007 - Movement - (52.11 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0002 - Movement - (12.84 SQM)	Not Applicable	Circulation or storage space.
B0C3 - R0004 - Art Learning Space - (43.96 SQM) - Teaching Space: 1	● Student Space (20)	
B0C3 - R0009 - Darkroom Space - (19.52 SQM)	● Office (4)	
B0C3 - R0010 - Seminar/Study - (27.46 SQM)	● Office (6)	
B0C3 - R0013 - Movement - (58.96 SQM)	Not Applicable	Circulation or storage space.
B0E1 - R0001 - Movement - (32.61 SQM)	Not Applicable	Circulation or storage space.
B0E1 - R0005 - Practical Activities - 1hb - (29.59 SQM)	● Student Space (13)	
B0E1 - R0010 - Home Base - (47.37 SQM) - Teaching Space: 1	● Student Space (21)	
B0E1 - R0011 - Home Base - (47.44 SQM) - Teaching Space: 1	● Student Space (22)	
B0E1 - R0012 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B0E1 - R0013 - Withdrawal Space - 1hb - (7.96 SQM)	● Student Space (3)	
B0E1 - R0014 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B0E2 - R0001 - Movement - (32.65 SQM)	Not Applicable	Circulation or storage space.
B0E2 - R0006 - Practical Activities - 1hb - (29.62 SQM)	● Student Space (13)	
B0E2 - R0009 - Home Base - (47.49 SQM) - Teaching Space: 1	● Student Space (22)	
B0E2 - R0010 - Home Base - (47.4 SQM) - Teaching Space: 1	● Student Space (21)	
B0E2 - R0011 - Movement - (9.38 SQM)	Not Applicable	Circulation or storage space.
B0E2 - R0012 - Withdrawal Space - 1hb - (7.97 SQM)	● Student Space (3)	
B0E2 - R0013 - Movement - (9.38 SQM)	Not Applicable	Circulation or storage space.
OS 601 15530 - OS 601 15530 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15531 - OS 601 15531 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	