


VENTILATION AUDIT REPORT

SCHOOL:	Wiley Park Public School (4553)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Lakemba
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

4553 - Wiley Park Public School
Site Plan (11402)



1:915

Printed: 05-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (25.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (58.7 SQM)	Office (14)	
B00A - R0003 - Staff Room Annexe - (25.61 SQM)	Office (6)	
B00A - R0009 - Principal - (14.94 SQM)	Office (3)	
B00A - R0010 - Interview - (9.18 SQM)	Office (2)	
B00A - R0011 - Movement - (13.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Clerical Office - (21.57 SQM)	Office (5)	
B00A - R0013 - Movement - (27.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Entry Vestibule - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Clerical Office/Workroom - (27.8 SQM)	Office (6)	
B00A - R0016 - Deputy Principal - (13.81 SQM)	Office (3)	
B00A - R0017 - Interview - (13.81 SQM)	Office (3)	
B00A - R0018 - Interview - (12.54 SQM)	Office (3)	
B00A - R0019 - Movement - (26.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Communal Space - (184.92 SQM)	Student Space (85)	
B00B - R0007 - Canteen - (44.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (31.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (16.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Raised Platform - (53.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (97.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (47.26 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0004 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0005 - Home Base - (47.39 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0006 - Home Base - (47.39 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0007 - Home Base - (48.8 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0008 - Home Base - (39.18 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0009 - Practical Activities - 1hb - (8.16 SQM)	Student Space (3)	
B00E - R0013 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (20.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Practical Activities - 1hb - (5.91 SQM)	Student Space (2)	
B00E - R0020 - Communal Space - (146.59 SQM)	Student Space (68)	
B00E - R0021 - Movement - (42.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Withdrawal Space - 1hb - (17.53 SQM)	Student Space (8)	
B00E - R0023 - Movement - (20.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (29.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1003 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1004 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1005 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1006 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1007 - Home Base - (48.26 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1010 - Movement - (112.61 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (24.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Special Programs Room - (36.28 SQM)	Student Space (16)	
B00F - R0003 - Special Programs Room - (31.64 SQM)	Student Space (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0005 - Special Programs Room - (22.84 SQM)	● Student Space (10)	
B00G - R0005 - Special Programs Room - (48.24 SQM)	● Student Space (22)	
B00G - R0006 - Home Base - (47.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0008 - Home Base - (47.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0009 - Home Base - (48.84 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0015 - Movement - (32.11 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (25.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Home Base - (47.76 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0020 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0025 - Movement - (103.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Movement - (11.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Home Base - (47.38 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0030 - Withdrawal Space - 1hb - (14.38 SQM)	● Student Space (6)	
B00G - R0031 - Practical Activities - 2hb - (15.83 SQM)	● Student Space (7)	
B00G - R0032 - Withdrawal Space - 1hb - (16.07 SQM)	● Student Space (7)	
B00G - R0033 - Home Base - (47.68 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1001 - Home Base - (43.63 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R1003 - Home Base - (48.81 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1004 - Home Base - (48.18 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1005 - Home Base - (48 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1007 - Home Base - (47.74 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1008 - Home Base - (47.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1010 - Movement - (125.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Home Base - (47.68 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1012 - Home Base - (48 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1013 - Staff Kitchen - (23.11 SQM)	● Office (5)	
B00G - R1019 - Withdrawal Space - 1hb - (14.77 SQM)	● Student Space (6)	
B00G - R1020 - Practical Activities - 2hb - (16.14 SQM)	● Student Space (7)	
B00G - R1021 - Withdrawal Space - 1hb - (16.33 SQM)	● Student Space (7)	
B00G - R1022 - Withdrawal Space - 2hb - (7.6 SQM)	● Student Space (3)	
B00H - R0001 - Movement - (34.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (19.98 SQM)	● Student Space (9)	
B00H - R0004 - Home Base - (59.02 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (59.02 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.98 SQM)	● Student Space (9)	
B00I - R0001 - Reading Area - (231.76 SQM)	● Student Space (107)	
OS 600 11344 - OS 600 11344 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 16339 - OS 601 16339 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	