

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Willawarrin Public School (3445)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Oxley</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Kempsey</b>

3445 - Willawarrin Public School  
Site Plan (11956)



1:758

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (60.11 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0002 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Room Annexe - (11.5 SQM)	 Office (2)	
B00A - R0004 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (60.11 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0006 - Practical Activities - 1hb - (14.14 SQM)	 Student Space (6)	
B00A - R0007 - Movement - (32.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Practical Activities - 1hb - (14.14 SQM)	 Student Space (6)	
B00B - R0006 - Canteen - (18.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Seminar/Study - (14.1 SQM)	 Office (3)	
B00B - R0009 - Reading Area - (37.38 SQM)	 Student Space (17)	
B00C - R0001 - Home Base - (51.62 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R0002 - Practical Activities - 1hb - (8.83 SQM)	 Student Space (4)	
B00D - R0001 - Movement - (20.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (41.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (212.76 SQM)	 Student Space (98)	
B00I - R0001 - Raised Platform - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Clerical Office - (17.62 SQM)	 Office (4)	
B00J - R0005 - Sick Bay - (7.39 SQM)	 Student Space (3)	
B00J - R0008 - Movement - (19.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Staff Room - (21.14 SQM)	 Office (5)	
B00J - R0010 - Staff Kitchen - (5.32 SQM)	 Office (1)	
B00J - R0012 - Principal - (15.73 SQM)	 Office (3)	
B00J - R0013 - Reading Area - (70.41 SQM)	 Student Space (32)	