

VENTILATION AUDIT REPORT

SCHOOL:	Willoughby Girls High School (8159)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Willoughby
LOCAL GOVERNMENT AREA:	Willoughby

8159 - Willoughby Girls High School
Site Plan (12818)



1:1,208

Printed: 16-Mar-2021

















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Materials Technology L.S. - (67.29 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0003 - Food Technology L.S. - (76.15 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R0004 - Kitchen - Type 1 - (77.45 SQM)	● Student Space (35)	
B00A - R0005 - Staff Study - (12.42 SQM)	○ Office (3)	
B00A - R0007 - Student Waiting - (8.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - General Learning Space - (47.7 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0015 - General Learning Space - (47.7 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0018 - Deputy Principal Office - (19.32 SQM)	○ Office (4)	
B00A - R0020 - Principal Office - (19.24 SQM)	○ Office (4)	
B00A - R0024 - General Learning Space - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0025 - General Learning Space - (47.77 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0026 - Interview/Office - Type 1 - (10.5 SQM)	○ Office (2)	
B00A - R0027 - General Learning Space - (47.91 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0029 - Interview/Meeting - (47.64 SQM)	○ Office (11)	
B00A - R0035 - Interview/Office - Type 1 - (10.35 SQM)	○ Office (2)	
B00A - R0036 - Leading Teacher - (9.87 SQM)	○ Office (2)	
B00A - R0037 - Preparation - (13.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Staff Study - (16.1 SQM)	○ Office (4)	
B00A - R0039 - Staff Study - (14.34 SQM)	○ Office (3)	
B00A - R0041 - Staff Study - (16.81 SQM)	○ Office (4)	
B00A - R0046 - Movement - (7.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (20.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Movement - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (48.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Movement - (12.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0059 - Clinic - Girls - (10.32 SQM)	○ Office (2)	
B00A - R0061 - Interview/Office - Type 1 - (7.86 SQM)	○ Office (1)	
B00A - R0062 - Deputy Principal Office - (11.66 SQM)	○ Office (2)	
B00A - R0063 - Administration - Clerical - (47.77 SQM)	○ Office (11)	
B00A - R0064 - Administration - Executive - (8.75 SQM)	○ Office (2)	
B00A - R0066 - Student Waiting - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0067 - Student Waiting - (9.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0068 - Movement - (181.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0069 - Commonroom - (34.32 SQM)	○ Office (8)	
B00A - R0070 - Staff Kitchen - (13.13 SQM)	○ Office (3)	
B00A - R0072 - Dark Room - (11.19 SQM)	○ Office (2)	
B00A - R1001 - Music Learning Space - (77.04 SQM) - Teaching Space: 1	● Student Space (35)	
B00A - R1002 - Design L.S. - (68.9 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1004 - Design/Technology L.S. - (70.15 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R1005 - Staff Study - (17.99 SQM)	○ Office (4)	
B00A - R1006 - General Learning Space - (54.26 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1008 - Study Space - (11.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - General Learning Space - (48.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1010 - General Learning Space - (48.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1011 - General Learning Space - (48.5 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1012 - Staff Study - (53.24 SQM)	○ Office (13)	
B00A - R1013 - Tea Room - (5.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Computer Learning Space - (48.57 SQM) - Teaching Space: 1	● Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1016 - General Learning Space - (48.64 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1017 - Staff Study - (21.37 SQM)	Office (5)	
B00A - R1018 - General Learning Space - (48.72 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1019 - General Learning Space - (48.71 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1020 - General Learning Space - (48.64 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1021 - Design/Technology L.S. - (74.47 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1022 - Staff Study - (30.23 SQM)	Office (7)	
B00A - R1034 - Movement - (223.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R9002 - Art Learning Space - (68.71 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R9005 - Multi Media Workshop - (47.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R9006 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - Staff Study - (19.33 SQM)	Office (4)	
B00A - R9009 - Art Learning Space - (47.5 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R9010 - Art Learning Space - (50.9 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R9014 - Movement - (15.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R9018 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R9019 - Workshop - (38.86 SQM)	Student Space (18)	
B00B - R0001 - Movement - (24.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Kitchen - (15.86 SQM)	Office (3)	
B00B - R0003 - Multi-Purpose Space - (404.77 SQM)	Student Space (187)	
B00B - R0013 - General Assistants - (11.66 SQM)	Office (2)	
B00B - R0023 - Stage - (67.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (52.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Movement - (51.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Study Space - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Study - (52.61 SQM)	Office (13)	
B00C - R0003 - General Learning Space - (47.08 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0004 - General Learning Space - (47.77 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0005 - General Learning Space - (45.47 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0007 - Movement - (54.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (101.41 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0003 - Preparation - Science - (24.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Laboratory L.S. - (52.36 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Preparation - Science - (25.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Laboratory L.S. - (101.19 SQM) - Teaching Space: 1	Student Space (46)	
B00D - R0012 - Movement - (47.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Laboratory L.S. - (84.31 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R1005 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1008 - Staff Study - (25.71 SQM)	Office (6)	
B00D - R1010 - Staff Study - (28.13 SQM)	Office (7)	
B00D - R1011 - Laboratory L.S. - (98.28 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R1012 - Movement - (49.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Senior Study - (10.72 SQM)	Office (2)	
B00E - R0002 - Senior Study - (21.86 SQM)	Office (5)	
B00E - R0012 - Main Area - (80.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Main Entry - (18.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Main Area - (219.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Study - (26.04 SQM)	Office (6)	
B00F - R0003 - Staff Study - (7.81 SQM)	Office (1)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0004 - Stage - (17.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Multi-Purpose Space - (112.52 SQM)	● Student Space (52)	
B00I - R0003 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Staff Study - (17.66 SQM)	● Office (4)	
B00I - R0007 - Staff Kitchen - (25.47 SQM)	● Office (6)	
B00K - R0001 - Shared Learning Space - (224.79 SQM)	● Student Space (104)	
B00K - R0008 - General Learning Space - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R0009 - Practical Activities - (9.64 SQM)	● Student Space (4)	
B00K - R0010 - General Learning Space - (58.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0011 - Practical Activities - (8.41 SQM)	● Student Space (3)	
B00K - R0015 - Senior Study - (123.32 SQM)	● Office (30)	
B00K - R0017 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00K - R0021 - Staff Kitchen - (12.2 SQM)	● Office (3)	
B00K - R0022 - Staff Study - (74.86 SQM)	● Office (18)	
B00K - R0027 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00K - R0029 - Movement - (14.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R0030 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0040 - Movement - (16.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R0041 - Movement - (16.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Shared Learning Space - (164.34 SQM)	● Student Space (76)	
B00K - R1003 - General Learning Space - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R1004 - General Learning Space - (60.42 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1007 - General Learning Space - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1008 - General Learning Space - (57.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R1009 - Isolation Space - (8.06 SQM)	● Office (2)	
B00K - R1012 - General Learning Space - (57.94 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R1013 - General Learning Space - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1016 - General Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R1017 - General Learning Space - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R1018 - Isolation Space - (8.13 SQM)	● Office (2)	
B00K - R1019 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R1020 - Movement - (16.14 SQM)	Not Applicable	Circulation or storage space.
B00K - R1021 - Movement - (16.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R1022 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R2001 - Shared Learning Space - (167.82 SQM)	● Student Space (77)	
B00K - R2002 - Practical Activities - (5.54 SQM)	● Student Space (2)	
B00K - R2003 - Outdoor Learning Area - (118.86 SQM)	Not Applicable	Circulation or storage space.
B00K - R2006 - General Learning Space - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R2007 - General Learning Space - (57.94 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R2008 - Isolation Space - (8.06 SQM)	● Office (2)	
B00K - R2011 - General Learning Space - (57.94 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R2012 - General Learning Space - (59.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R2015 - General Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00K - R2016 - General Learning Space - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R2017 - Isolation Space - (8.13 SQM)	● Office (2)	
B00K - R2018 - Movement - (16.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R2019 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R2020 - Movement - (16.29 SQM)	Not Applicable	Circulation or storage space.
B00K - R2021 - Movement - (16.47 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 11538 - OS 600 11538 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 11552 - OS 600 11552 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 12309 - OS 600 12309 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 13941 - OS 600 13941 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 14246 - OS 600 14246 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15115 - OS 600 15115 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15893 - OS 600 15893 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17837 - OS 600 17837 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17838 - OS 600 17838 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17839 - OS 600 17839 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18032 - OS 600 18032 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18192 - OS 600 18192 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18354 - OS 600 18354 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18362 - OS 600 18362 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 13796 - OS 601 13796 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13970 - OS 601 13970 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	