

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Willyama High School (8491)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Barwon</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Broken Hill</b>

8491 - Willyama High School  
Site Plan (10808)



1:2,183

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0E01 - Welding Area - (9.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0E04 - Materials Technology L.S. - (179.68 SQM) - Teaching Space: 1	● Student Space (83)	
B00A - R0E05 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0E06 - Design L.S. - (51.13 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0E07 - Design L.S. - (51.27 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0E09 - Materials Technology L.S. - (205.31 SQM) - Teaching Space: 1	● Student Space (95)	
B00A - R0E11 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0E13 - Staff Study - (13.54 SQM)	○ Office (3)	
B00A - R0E14 - Staff Study - (25.99 SQM)	○ Office (6)	
B00A - R0E24 - Movement - (131.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0E25 - General Learning Space - (58.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0E26 - General Learning Space - (58.65 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0N08 - Staff Study - (30.2 SQM)	○ Office (7)	
B00A - R0N09 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0N10 - Staff Study - (30.17 SQM)	○ Office (7)	
B00A - R0N11 - Practice/Seminar - (65.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0N12 - Music Learning Space - (65.33 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0N16 - Student Canteen - (45.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0N19 - Movement - (245.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S01 - Movement - (21.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S02 - Movement - (88.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S07 - Movement - (25.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S08 - Multi-Purpose Space - (455 SQM)	● Student Space (211)	
B00A - R0S09 - Movement - (88.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S14 - Movement - (13.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S19 - Movement - (8.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S20 - Movement - (76.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S22 - Practice/Seminar - (97.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0S29 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0W02 - Movement - (16.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0W08 - Darkroom Space - (13.6 SQM)	○ Office (3)	
B00A - R0W09 - Duplicating Workroom - (22.54 SQM)	○ Office (5)	
B00A - R0W10 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0W12 - Art Learning Space - (54.79 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0W14 - Art Learning Space - (72.31 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R0W16 - Workshop Area - (53.24 SQM)	● Student Space (24)	
B00A - R0W18 - Art Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0W22 - Duplicating Workroom - (5.64 SQM)	○ Office (1)	
B00A - R0W23 - Materials Technology L.S. - (65.15 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0W26 - Special Learning Space - (64.46 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0W29 - Staff Study - (12.56 SQM)	○ Office (3)	
B00A - R0W32 - Movement - (173.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0W34 - Food Technology L.S. - (94.31 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0W37 - Food/Research Space - (21.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0W39 - Food Technology L.S. - (88.54 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0W40 - Movement - (17.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1E01 - Laboratory L.S. - (88.93 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1E02 - Preparation - (53.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1E03 - Laboratory L.S. - (88.73 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1E10 - Staff Study - (29.31 SQM)	○ Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1E11 - General Learning Space - (52.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1E12 - Computer Learning Space - (84.37 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R1E14 - General Learning Space - (52.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1E15 - Staff Study - (29.59 SQM)	● Office (7)	
B00A - R1E18 - Staff Study - (12.57 SQM)	● Office (3)	
B00A - R1E20 - Laboratory L.S. - (88.88 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1E21 - Preparation - (52.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1E22 - Laboratory L.S. - (88.48 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1E26 - Movement - (308.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1E27 - Movement - (161.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1E28 - Movement - (90.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1N01 - Commonroom - (149.74 SQM)	● Office (37)	
B00A - R1N03 - Workroom - (64.08 SQM)	● Office (16)	
B00A - R1N05 - Main Area - (194.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1N06 - Entry - (32.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1N10 - Movement - (155.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1N11 - Movement - (50.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S01 - Deputy Principal Office - (18.37 SQM)	● Office (4)	
B00A - R1S02 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S03 - Public Entry - (98.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S05 - Movement - (43.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S06 - Clinic - Boys - (12.45 SQM)	● Office (3)	
B00A - R1S07 - Duplicating Workroom - (22.16 SQM)	● Office (5)	
B00A - R1S08 - Administration - Clerical - (17.82 SQM)	● Office (4)	
B00A - R1S09 - Principal Office - (27.86 SQM)	● Office (6)	
B00A - R1S14 - Administration - Clerical - (11.82 SQM)	● Office (2)	
B00A - R1S15 - Administration - Clerical - (27.12 SQM)	● Office (6)	
B00A - R1S18 - Movement - (66.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S19 - Movement - (76.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1S20 - Movement - (75.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1W01 - Staff Study - (12.3 SQM)	● Office (3)	
B00A - R1W09 - Senior Seminar - (17.77 SQM)	● Office (4)	
B00A - R1W11 - General Learning Space - (50.96 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W12 - General Learning Space - (51.69 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W13 - General Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W15 - Computer Learning Space - (85.04 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R1W16 - General Learning Space - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W17 - General Learning Space - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1W19 - General Learning Space - (51.31 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W20 - General Learning Space - (51.9 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1W21 - General Learning Space - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1W22 - General Learning Space - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1W23 - Staff Study - (29.6 SQM)	● Office (7)	
B00A - R1W25 - Staff Study - (65.89 SQM)	● Office (16)	
B00A - R1W28 - Movement - (458.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R2E01 - Laboratory L.S. - (89.07 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R2E02 - Preparation - (52.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R2E03 - Laboratory L.S. - (88.57 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R2E08 - Music Learning Space - (84.6 SQM) - Teaching Space: 1	● Student Space (39)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R2E09 - General Learning Space - (52.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2E10 - General Learning Space - (52.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2E11 - Commonroom - (106.19 SQM)	○ Office (26)	
B00A - R2E18 - Laboratory L.S. - (88.76 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R2E19 - Preparation - (53.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R2E20 - Laboratory L.S. - (88.55 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R2E22 - Movement - (260.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R2N01 - General Learning Space - (121.15 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R2N05 - Main Area - (218.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R2N07 - Workroom - (15.55 SQM)	○ Office (3)	
B00A - R2N09 - Interview/Office - Type 1 - (14.8 SQM)	○ Office (3)	
B00A - R2N10 - Interview/Office - Type 1 - (14.85 SQM)	○ Office (3)	
B00A - R2N11 - Audio Visual Workroom - (29.72 SQM)	● Student Space (13)	
B00A - R2N12 - Workroom - (15.51 SQM)	○ Office (3)	
B00A - R2N13 - Staff Study - (16.95 SQM)	○ Office (4)	
B00A - R2N17 - Movement - (155.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R2W07 - Staff Study - (28.12 SQM)	○ Office (7)	
B00A - R2W08 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2W09 - General Learning Space - (51.69 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2W10 - General Learning Space - (50.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2W11 - Computer Learning Space - (84.68 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R2W12 - General Learning Space - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2W13 - General Learning Space - (52.11 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2W14 - Duplicating Workroom - (21.46 SQM)	○ Office (5)	
B00A - R2W15 - Staff Study - (21.46 SQM)	○ Office (5)	
B00A - R2W16 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2W17 - Interview/Office - Type 1 - (52.63 SQM)	○ Office (13)	
B00A - R2W18 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2W19 - General Learning Space - (51.84 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2W20 - General Learning Space - (51.84 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R2W21 - General Learning Space - (51.11 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2W24 - Movement - (413.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Workshop Area - (126.65 SQM)	● Student Space (58)	