

VENTILATION AUDIT REPORT

SCHOOL:	Wingham Public School (7314)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

7314 - Wingham Public School
Site Plan (12910)



1:1,272

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (54.45 SQM)	Office (13)	
B00A - R0003 - Principal - (17.68 SQM)	Office (4)	
B00A - R0004 - Clerical Office/Workroom - (32.45 SQM)	Office (8)	
B00A - R0005 - Staff Room Annexe - (13.79 SQM)	Office (3)	
B00A - R0006 - Entry Vestibule - (13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Deputy Principal - (14.8 SQM)	Office (3)	
B00A - R0008 - Sick Bay - (8.95 SQM)	Student Space (4)	
B00A - R0013 - Staff Room Annexe - (12.81 SQM)	Office (3)	
B00A - R0014 - Movement - (44.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Clerical Office - (12.82 SQM)	Office (3)	
B00A - R0018 - Movement - (9.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Withdrawal Space - 1hb - (6.36 SQM)	Student Space (2)	
B00B - R0004 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0005 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Practical Activities - 1hb - (36.53 SQM)	Student Space (16)	
B00B - R0007 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0009 - Withdrawal Space - 1hb - (12.96 SQM)	Student Space (6)	
B00B - R0012 - Home Base - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0013 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Practical Activities - 1hb - (36.48 SQM)	Student Space (16)	
B00B - R0015 - Home Base - (59.98 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0017 - Withdrawal Space - 1hb - (6.36 SQM)	Student Space (2)	
B00B - R0018 - Movement - (32.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (16.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Withdrawal Space - 1hb - (6.32 SQM)	Student Space (2)	
B00C - R0004 - Home Base - (59.83 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Movement - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practical Activities - 1hb - (36.15 SQM)	Student Space (16)	
B00C - R0007 - Movement - (16.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0012 - Withdrawal Space - 1hb - (6.3 SQM)	Student Space (2)	
B00D - R0001 - Movement - (41.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Canteen - (43.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 1hb - (6.19 SQM)	Student Space (2)	
B00E - R0004 - Home Base - (60.39 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0005 - Movement - (9.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Practical Activities - 1hb - (37.39 SQM)	Student Space (17)	
B00E - R0007 - Movement - (16.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0012 - Withdrawal Space - 1hb - (12.96 SQM)	Student Space (6)	
B00E - R0014 - Home Base - (59.98 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0015 - Movement - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Practical Activities - 1hb - (36.49 SQM)	Student Space (16)	
B00E - R0018 - Movement - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0020 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0024 - Movement - (88.77 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Withdrawal Space - 1hb - (6.18 SQM)	● Student Space (2)	
B00F - R0004 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0005 - Movement - (9.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - 1hb - (37.49 SQM)	● Student Space (17)	
B00F - R0007 - Movement - (16.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0011 - Withdrawal Space - 1hb - (12.96 SQM)	● Student Space (6)	
B00F - R0014 - Home Base - (59.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0015 - Movement - (8.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Practical Activities - 1hb - (37.49 SQM)	● Student Space (17)	
B00F - R0017 - Movement - (16.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Home Base - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0023 - Movement - (88.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (89.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Communal Space - (214.18 SQM)	● Student Space (99)	
B00H - R0012 - Interview - (13.21 SQM)	● Office (3)	
B00H - R0014 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Raised Platform - (36.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Reading Area - (77.72 SQM)	● Student Space (36)	
B00L - R0002 - Reading Area - (105.63 SQM)	● Student Space (49)	
B00L - R0003 - Reading Area - (41.42 SQM)	● Student Space (19)	
B00L - R0006 - Seminar/Study - (13.55 SQM)	● Office (3)	
B00L - R0007 - Movement - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0011 - Special Programs Room - (38.28 SQM)	● Student Space (17)	
B00L - R0014 - Movement - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Canteen - (8.35 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0001 - Special Programs Room - (38.52 SQM)	● Student Space (17)	