

VENTILATION AUDIT REPORT

SCHOOL:	Winmalee High School (8573)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

8573 - Winmalee High School
Site Plan (13203)



1:1,618

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview/Office - Type 1 - (13.95 SQM)	Office (3)	
B00A - R0002 - Interview/Office - Type 1 - (12.77 SQM)	Office (3)	
B00A - R0003 - Principal Office - (19.54 SQM)	Office (4)	
B00A - R0005 - Ancillary Staff - (22.27 SQM)	Office (5)	
B00A - R0008 - Laboratory L.S. - (81.22 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0009 - Preparation - (20.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (53.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Study - (38.41 SQM)	Office (9)	
B00A - R0014 - Duplicating Workroom - (26.62 SQM)	Office (6)	
B00A - R0015 - Administration - Clerical - (45.03 SQM)	Office (11)	
B00A - R0016 - Public Entry - (46.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Pupil Entry - (57.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Deputy Principal Office - (14.48 SQM)	Office (3)	
B00A - R0020 - Clinic - Boys - (14.48 SQM)	Office (3)	
B00A - R0023 - Clinic - Girls - (13.88 SQM)	Office (3)	
B00B - R0001 - Growing/Breeding - (19.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Laboratory L.S. - (81.04 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0003 - Preparation - (31.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Laboratory L.S. - (81.03 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0005 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Laboratory L.S. - (81.03 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0012 - Preparation - (31.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Laboratory L.S. - (81.04 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0014 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (183.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Design L.S. - (69.16 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0002 - Food Technology L.S. - (105.34 SQM) - Teaching Space: 1	Student Space (48)	
B00C - R0003 - Food/Research Space - (14.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Preparation - (20.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Food Technology L.S. - (105.34 SQM) - Teaching Space: 1	Student Space (48)	
B00C - R0007 - Design L.S. - (69.16 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0011 - Staff Study - (25.04 SQM)	Office (6)	
B00C - R0012 - Movement - (82.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Food/Research Space - (28.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Study - (23.44 SQM)	Office (5)	
B00D - R0002 - Teachers Aides - (13.43 SQM)	Office (3)	
B00D - R0003 - Study Space - (15.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0005 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0008 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R0009 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0010 - Darkroom Space - (31.32 SQM)	Office (7)	
B00D - R0012 - Interview/Office - Type 1 - (15.01 SQM)	Office (3)	
B00D - R0014 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (233.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1002 - General Learning Space - (48.35 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1005 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1006 - Computer Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1007 - Study Space - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Staff Study - (39.45 SQM)	Office (9)	
B00D - R1011 - General Learning Space - (39.45 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R1012 - General Learning Space - (39.45 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R1013 - General Learning Space - (39.44 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R1014 - Study Space - (15.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Movement - (122.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Seminar - (11.83 SQM)	Office (2)	
B00E - R0002 - Seminar - (10.46 SQM)	Office (2)	
B00E - R0003 - Seminar - (10.97 SQM)	Office (2)	
B00E - R0005 - Audio Visual Workroom - (25.51 SQM)	Student Space (11)	
B00E - R0006 - Workroom - (35.53 SQM)	Office (8)	
B00E - R0008 - Main Area - (366.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (112.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Commonroom - (93.88 SQM)	Office (23)	
B00E - R1003 - Computer Learning Space - (71 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R1005 - Study Space - (11.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Study - (15.25 SQM)	Office (3)	
B00F - R0002 - General Learning Space - (39.18 SQM) - Teaching Space: 1	Student Space (18)	
B00F - R0003 - General Learning Space - (51.85 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0004 - General Learning Space - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0007 - General Learning Space - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0008 - General Learning Space - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0011 - Movement - (14.83 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Staff Study - (23.54 SQM)	Office (5)	
B00F - R0013 - Movement - (16.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (217.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - General Learning Space - (28.73 SQM) - Teaching Space: 1	Student Space (13)	
B00F - R1001 - General Learning Space - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1002 - General Learning Space - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1005 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1006 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1007 - Study Space - (15.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R1008 - General Learning Space - (39.43 SQM) - Teaching Space: 1	Student Space (18)	
B00F - R1009 - General Learning Space - (39.43 SQM) - Teaching Space: 1	Student Space (18)	
B00F - R1010 - General Learning Space - (39.44 SQM) - Teaching Space: 1	Student Space (18)	
B00F - R1011 - Staff Study - (39.43 SQM)	Office (9)	
B00F - R1013 - Study Space - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R1018 - Movement - (200.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Staff Study - (21.56 SQM)	Office (5)	
B00G - R0003 - Art Learning Space - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0004 - Workshop - (59.43 SQM)	Student Space (27)	
B00G - R0005 - Art Learning Space - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Art Learning Space - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0011 - Movement - (102.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - General Learning Space - (32.35 SQM) - Teaching Space: 1	Student Space (15)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1001 - Music Learning Space - (78.34 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R1002 - Practice/Seminar - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00G - R1004 - Practice/Seminar - (25.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Music Learning Space - (60.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R1006 - Movement - (85.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R1010 - Staff Study - (28.44 SQM)	● Office (7)	
B00G - R1012 - General Learning Space - (32.32 SQM) - Teaching Space: 1	● Student Space (14)	
B00H - R0003 - Materials Technology L.S. - (91.84 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0004 - Wood Technology Bay - (33.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Materials Technology L.S. - (91.85 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0007 - Materials Technology L.S. - (91.84 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0008 - Metal Technology Bay - (35.07 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Materials Technology L.S. - (91.85 SQM) - Teaching Space: 1	● Student Space (42)	
B00H - R0010 - Workshop Area - (62.56 SQM)	● Student Space (29)	
B00H - R0015 - Interview/Office - Type 1 - (25.22 SQM)	● Office (6)	
B00H - R0024 - Movement - (121.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Movement - (51.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0029 - Welding/Hot Metals Area - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Design L.S. - (58.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1003 - Design L.S. - (58.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R1004 - Staff Study - (20.26 SQM)	● Office (5)	
B00H - R1005 - Movement - (42.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - General Assistants - (12.18 SQM)	● Office (3)	
B00J - R0006 - Staff Study - (15.99 SQM)	● Office (3)	
B00J - R0007 - Multi-Purpose Space - (461.67 SQM)	● Student Space (214)	
B00J - R0008 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (15.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Stage - (89.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Commonroom - (26.74 SQM)	● Office (6)	
B00J - R0015 - Movement - (15.76 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R0028 - Movement - (251.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (35.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R1004 - Tiered Learning Area - (64.55 SQM)	● Student Space (29)	
B00L - R0006 - Student Canteen - (62.4 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Movement - (38.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement Studio - (181.02 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement Studio - (30.71 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.