


VENTILATION AUDIT REPORT

SCHOOL:	Winmalee Public School (4436)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blue Mountains
LOCAL GOVERNMENT AREA:	Blue Mountains

4436 - Winmalee Public School
Site Plan (11406)



1:954

Printed: 27-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room - (54.92 SQM)	Office (13)	
B00A - R0003 - Entry Vestibule - (23.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (12.78 SQM)	Office (3)	
B00A - R0005 - Sick Bay - (12.96 SQM)	Student Space (6)	
B00A - R0006 - Deputy Principal - (13 SQM)	Office (3)	
B00A - R0008 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (21.06 SQM)	Office (5)	
B00A - R0014 - Duplicating Workroom - (12.83 SQM)	Office (3)	
B00A - R0016 - Movement - (5.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Room Annexe - (13.77 SQM)	Office (3)	
B00B - R0012 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Interview - (13.48 SQM)	Office (3)	
B00C - R0002 - Practical Activities - 1hb - (22.81 SQM)	Student Space (10)	
B00C - R0021 - Home Base - (63.92 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0022 - Practical Activities - 1hb - (24.22 SQM)	Student Space (11)	
B00C - R0030 - Movement - (19.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Special Programs Room - (5.54 SQM)	Student Space (2)	
B00C - R0032 - Special Programs Room - (15.95 SQM)	Student Space (7)	
B00C - R0033 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0035 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Home Base - (58.07 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1002 - Practical Activities - 1hb - (11.29 SQM)	Student Space (5)	
B00C - R1009 - Home Base - (49.57 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1010 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00C - R1012 - Practical Activities - 1hb - (10.57 SQM)	Student Space (4)	
B00C - R1013 - Home Base - (48.91 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R1022 - Home Base - (58.3 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1023 - Practical Activities - 1hb - (11.12 SQM)	Student Space (5)	
B00C - R1025 - Movement - (32.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R1026 - Movement - (9.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R1027 - Movement - (16.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Seminar/Study - (8.91 SQM)	Office (2)	
B00L - R0003 - Reading Area - (118.95 SQM)	Student Space (55)	
B00L - R0007 - Movement - (11.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Seminar/Study - (8.67 SQM)	Office (2)	
B00P - R0002 - Home Base - (50.3 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0003 - Practical Activities - 1hb - (19.17 SQM)	Student Space (8)	
B00P - R0004 - Movement - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Movement - (10.72 SQM)	Not Applicable	Circulation or storage space.
B00P - R0008 - Practical Activities - 1hb - (18.45 SQM)	Student Space (8)	
B00P - R0009 - Home Base - (49.82 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0010 - Withdrawal Space - 1hb - (11.09 SQM)	Student Space (5)	
B00P - R0012 - Home Base - (50.12 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0013 - Practical Activities - 1hb - (18.6 SQM)	Student Space (8)	
B00P - R0014 - Practical Activities - 1hb - (19.14 SQM)	Student Space (8)	
B00P - R0015 - Home Base - (49.81 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R0016 - Withdrawal Space - 1hb - (11 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0001 - Communal Space - (200.19 SQM)	● Student Space (92)	
B00Q - R0002 - Raised Platform - (58.15 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0003 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0005 - Movement - (11.37 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Home Base - (41.23 SQM)	● Student Space (19)	
B00R - R0002 - Clerical Office - (11.33 SQM)	● Office (2)	
B00R - R0003 - Practical Activities - (16.96 SQM)	● Student Space (7)	
B00R - R0005 - Home Base - (68.94 SQM)	● Student Space (31)	
B0PS - R0002 - Communal Space - (174.95 SQM)	● Student Space (81)	
B0PS - R0005 - Raised Platform - (37.55 SQM)	Not Applicable	Circulation or storage space.
B0PS - R0006 - Movement - (7.08 SQM)	Not Applicable	Circulation or storage space.
B0PS - R0009 - Practical Activities - 1hb - (19.25 SQM)	● Student Space (8)	
B0PS - R0010 - Home Base - (48.8 SQM) - Teaching Space: 1	● Student Space (22)	
B0PS - R0011 - Withdrawal Space - 1hb - (11.26 SQM)	● Student Space (5)	
B0PS - R0012 - Home Base - (49.36 SQM) - Teaching Space: 1	● Student Space (22)	
B0PS - R0013 - Practical Activities - 1hb - (19.07 SQM)	● Student Space (8)	
B0PS - R0014 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B0PS - R1001 - Movement - (30.86 SQM)	Not Applicable	Circulation or storage space.
B0PS - R1002 - Practical Activities - 1hb - (19.57 SQM)	● Student Space (9)	
B0PS - R1003 - Home Base - (49.42 SQM) - Teaching Space: 1	● Student Space (22)	
B0PS - R1004 - Withdrawal Space - 1hb - (11.16 SQM)	● Student Space (5)	
B0PS - R1005 - Home Base - (49.71 SQM) - Teaching Space: 1	● Student Space (23)	
B0PS - R1006 - Practical Activities - 1hb - (19.8 SQM)	● Student Space (9)	
B0PS - R1007 - Movement - (16.92 SQM)	Not Applicable	Circulation or storage space.
B0PS - R1008 - Movement - (16.92 SQM)	Not Applicable	Circulation or storage space.
B0PS - R9007 - Movement - (34.79 SQM)	Not Applicable	Circulation or storage space.
OS 603 18173 - OS 603 18173 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	