

VENTILATION AUDIT REPORT

SCHOOL:	Winston Hills Public School (4417)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Parramatta

4417 - Winston Hills Public School
Site Plan (11407)



1:1,005

Printed: 12-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0013 - Duplicating Workroom - (9.47 SQM)	Office (2)	
B00A - R0014 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (15.96 SQM)	Office (3)	
B00A - R0018 - Movement - (35.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Principal - (15.78 SQM)	Office (3)	
B00A - R0022 - Duplicating Workroom - (15.13 SQM)	Office (3)	
B00A - R0024 - Interview - (10.22 SQM)	Office (2)	
B00A - R0027 - Sick Bay - (9.39 SQM)	Student Space (4)	
B00A - R0030 - Duplicating Workroom - (12.68 SQM)	Office (3)	
B00A - R0031 - Home Base - (55.86 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0032 - Practical Activities - 1hb - (13.28 SQM)	Student Space (6)	
B00A - R0033 - Practical Activities - 1hb - (14.02 SQM)	Student Space (6)	
B00A - R0034 - Home Base - (54 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0041 - Canteen - (27.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Staff Room - (81.75 SQM)	Office (20)	
B00A - R0046 - Staff Kitchen - (6.04 SQM)	Office (1)	
B00A - R0047 - Clerical Office/Workroom - (12.67 SQM)	Office (3)	
B00A - R0050 - Clerical Office - (25.62 SQM)	Office (6)	
B00B - R0003 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Home Base - (86.47 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0015 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0004 - Home Base - (86.35 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R0007 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0008 - Home Base - (56.87 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0020 - Staff Room Annexe - (13.36 SQM)	Office (3)	
B00F - R0021 - Home Base - M - (71.53 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0022 - Home Base - M - (71.61 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0024 - Staff Kitchen - (38.43 SQM)	Office (9)	
B00F - R0025 - Movement - (10.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Interview - (31.88 SQM)	Office (7)	
B00F - R0027 - Movement - (18.11 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (57.66 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0008 - Practical Activities - 1hb - (16.89 SQM)	Student Space (7)	
B00G - R0009 - Home Base - (84.28 SQM) - Teaching Space: 1	Student Space (39)	
B00G - R0010 - Home Base - (58.04 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0011 - Practical Activities - 1hb - (13.57 SQM)	Student Space (6)	
B00G - R0012 - Practical Activities - 1hb - (13.39 SQM)	Student Space (6)	
B00H - R0002 - Practical Activities - 1hb - (10.8 SQM)	Student Space (5)	
B00H - R0003 - Home Base - (56.24 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0004 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Entry Vestibule - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Reading Area - (145.28 SQM)	Student Space (67)	
B00H - R0017 - Reading Area - (74.73 SQM)	Student Space (34)	
B00H - R0022 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Home Base - (56.31 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0025 - Practical Activities - 1hb - (10.71 SQM)	Student Space (4)	
B00H - R0029 - Home Base - (55.73 SQM) - Teaching Space: 1	Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0030 - Practical Activities - 1hb - (10.74 SQM)	● Student Space (4)	
B00H - R0032 - Movement - (13.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0033 - Outdoor Learning Area - (109.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Practical Activities - 1hb - (10.77 SQM)	● Student Space (4)	
B00H - R1002 - Home Base - (56.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R1003 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Home Base - (56.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R1006 - Practical Activities - 1hb - (10.77 SQM)	● Student Space (4)	
B00H - R1008 - Home Base - (56.42 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R1009 - Practical Activities - 1hb - (10.77 SQM)	● Student Space (4)	
B00I - R0005 - Communal Space - (144.53 SQM)	● Student Space (67)	
B00I - R0006 - Clerical Office - (15.97 SQM)	● Office (3)	
B00I - R0007 - Staff Kitchen - (5.1 SQM)	● Office (1)	
B00J - R0002 - Home Base - (63.42 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0007 - Home Base - (63.98 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0008 - Home Base - (64.22 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0009 - Home Base - (63.9 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1001 - Home Base - (64.23 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1002 - Practical Activities - 1hb - (52.88 SQM)	● Student Space (24)	
B00J - R1003 - Home Base - (64.31 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1004 - Home Base - (64.47 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1010 - Home Base - (64.15 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R1013 - Movement - (51.54 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Communal Space - (198.63 SQM)	● Student Space (92)	
B00L - R0002 - Raised Platform - (55.43 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (8.54 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (18.59 SQM)	Not Applicable	Circulation or storage space.
OS 602 11898 - OS 602 11898 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19496 - OS 602 19496 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14962 - OS 603 14962 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 15689 - OS 606 15689 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 11099 - OS 750 11099 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	