


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Wiripaang Public School (3762)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

3762 - Wiripaang Public School  
Site Plan (10620)



1:2,340

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Movement - (47.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Deputy Principal - (18.41 SQM)	Office (4)	
B00A - R0008 - Staff Room - (14.18 SQM)	Office (3)	
B00A - R0009 - Movement - (20.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (39.1 SQM)	Office (9)	
B00A - R0012 - Staff Room - (8 SQM)	Office (2)	
B00A - R0014 - Deputy Principal - (18.83 SQM)	Office (4)	
B00B - R0001 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (15.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (57.48 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0007 - Home Base - (57.62 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0011 - Home Base - (56.97 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0014 - Movement - (6.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (55.7 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0004 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (55.47 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0007 - Home Base - (55.48 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0010 - Movement - (15.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (55.39 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0004 - Reading Area - (93.82 SQM)	Student Space (43)	
B00F - R0003 - Special Programs Room - (62.14 SQM)	Student Space (28)	
B00F - R0005 - Canteen - (41.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (53.55 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0012 - Movement - (15.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (44.29 SQM) - Teaching Space: 1	Student Space (20)	
B00H - R0007 - Withdrawal Space - 2hb - (21.89 SQM)	Student Space (10)	
B00H - R0011 - Home Base - (44.23 SQM) - Teaching Space: 1	Student Space (20)	
B00H - R0012 - Practical Activities - 2hb - (31.56 SQM)	Student Space (14)	
B00I - R0003 - Home Base - M - (43.62 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0004 - Practical Activities - M - 1hb - (25.5 SQM)	Student Space (11)	
B00J - R0001 - Staff Room - (66.95 SQM)	Office (16)	
B00J - R0003 - Movement - (10.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Home Base - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0006 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0009 - Movement - (15.63 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Home Base - (56.92 SQM) - Teaching Space: 1	Student Space (26)	