


VENTILATION AUDIT REPORT

SCHOOL:	Wirreanda Public School (4564)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

4564 - Wirreanda Public School
Site Plan (12912)



1:1,809

Printed: 01-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0009 - Practical Activities - 1hb - (39.98 SQM)	● Student Space (18)	
B00A - R0014 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0016 - Withdrawal Space - 1hb - (11.02 SQM)	● Student Space (5)	
B00B - R0003 - Canteen - (27.47 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (45.09 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Raised Platform - (71.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Communal Space - (124.07 SQM)	● Student Space (57)	
B00C - R0002 - Staff Room Annexe - (21.06 SQM)	● Office (5)	
B00C - R0003 - Movement - (41.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Clerical Office - (12.27 SQM)	● Office (3)	
B00C - R0010 - Staff Room Annexe - (13.99 SQM)	● Office (3)	
B00C - R0012 - Duplicating Workroom - (20.93 SQM)	● Office (5)	
B00C - R0013 - Sick Bay - (9.3 SQM)	● Student Space (4)	
B00C - R0014 - Clerical Office - (12.87 SQM)	● Office (3)	
B00C - R0015 - Principal - (16.92 SQM)	● Office (4)	
B00C - R0016 - Deputy Principal - (12.8 SQM)	● Office (3)	
B00C - R0019 - Entry Vestibule - (10.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Staff Room - (97.38 SQM)	● Office (24)	
B00C - R0024 - Staff Kitchen - (27.91 SQM)	● Office (6)	
B00C - R0026 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0009 - Practical Activities - 1hb - (39.86 SQM)	● Student Space (18)	
B00D - R0014 - Home Base - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0016 - Withdrawal Space - 1hb - (11 SQM)	● Student Space (5)	
B00E - R0002 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0006 - Practical Activities - 1hb - (39.95 SQM)	● Student Space (18)	
B00E - R0014 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0016 - Withdrawal Space - 1hb - (11.04 SQM)	● Student Space (5)	
B00F - R0002 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0006 - Practical Activities - 1hb - (39.88 SQM)	● Student Space (18)	
B00F - R0014 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0016 - Withdrawal Space - 1hb - (11.04 SQM)	● Student Space (5)	
B00G - R0001 - Reading Area - (168.67 SQM)	● Student Space (78)	
B00G - R0004 - Special Programs Room - (30.53 SQM)	● Student Space (14)	
B00H - R0003 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0009 - Practical Activities - 1hb - (39.86 SQM)	● Student Space (18)	
B00H - R0014 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0016 - Withdrawal Space - 1hb - (11.04 SQM)	● Student Space (5)	
B00J - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00J - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00J - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00K - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00L - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00L - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00M - R0002 - Practical Activities - 1hb - (19 SQM)	● Student Space (8)	
B00M - R0004 - Home Base - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0005 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00M - R0006 - Practical Activities - 1hb - (19.04 SQM)	● Student Space (8)	
B00M - R0007 - Home Base - (60.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0002 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00N - R0004 - Home Base - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0005 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00N - R0006 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00N - R0007 - Home Base - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0009 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00N - R0011 - Home Base - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0012 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00N - R0013 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00N - R0014 - Home Base - (60.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0003 - Raised Platform - (50.11 SQM)	Not Applicable	Circulation or storage space.
B00O - R0016 - Communal Space - (211 SQM)	● Student Space (97)	
B00O - R0019 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
OS 602 15917 - OS 602 15917 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10287 - OS 603 10287 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	