

VENTILATION AUDIT REPORT

SCHOOL:	Wollar Public School (3473)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Upper Hunter
LOCAL GOVERNMENT AREA:	Mid-Western

3473 - Wollar Public School
Site Plan (10483)








1:527

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (7.75 SQM)	 Office (1)	
B00A - R0003 - Reading Area - (31.3 SQM)	 Student Space (14)	
B00A - R0004 - Practical Activities - 1hb - (22.94 SQM)	 Student Space (10)	
B00A - R0005 - Duplicating Workroom - (14.31 SQM)	 Office (3)	
B00A - R0006 - Movement - (8.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Entry Vestibule - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Outdoor Learning Area - (20.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (59.93 SQM)	 Student Space (27)	