

VENTILATION AUDIT REPORT

SCHOOL:	Wollongbar Public School (3475)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Ballina

3475 - Wollongbar Public School
Site Plan (11628)












1:997

Printed: 15-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (100.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room Annexe - (19.53 SQM)	Office (4)	
B00A - R0003 - Staff Room - (45.79 SQM)	Office (11)	
B00A - R0009 - Deputy Principal - (12.74 SQM)	Office (3)	
B00A - R0011 - Deputy Principal - (13.15 SQM)	Office (3)	
B00A - R0012 - Principal - (16.83 SQM)	Office (4)	
B00A - R0013 - Interview - (13.19 SQM)	Office (3)	
B00A - R0015 - Sick Bay - (8.6 SQM)	Student Space (3)	
B00A - R0016 - Duplicating Workroom - (20.1 SQM)	Office (5)	
B00A - R0020 - Entry Vestibule - (20.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Clerical Office/Workroom - (24.82 SQM)	Office (6)	
B00A - R0031 - Movement - (34.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (143.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (19.34 SQM)	Student Space (8)	
B00B - R0005 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Withdrawal Space - 1hb - (11.72 SQM)	Student Space (5)	
B00B - R0007 - Home Base - (58.24 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0009 - Practical Activities - 1hb - (19.31 SQM)	Student Space (8)	
B00B - R0013 - Reading Area - (161.6 SQM)	Student Space (74)	
B00B - R0015 - Special Programs Room - (31.41 SQM)	Student Space (14)	
B00C - R0001 - Movement - (43.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Practical Activities - 1hb - (19.49 SQM)	Student Space (9)	
B00C - R0004 - Home Base - (57.99 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Withdrawal Space - 1hb - (11.76 SQM)	Student Space (5)	
B00C - R0008 - Home Base - (57.95 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0010 - Practical Activities - 1hb - (19.53 SQM)	Student Space (9)	
B00D - R0002 - Practical Activities - 1hb - (19.62 SQM)	Student Space (9)	
B00D - R0003 - Home Base - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0005 - Withdrawal Space - 1hb - (11.69 SQM)	Student Space (5)	
B00D - R0006 - Home Base - (58.22 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0008 - Practical Activities - 1hb - (19.45 SQM)	Student Space (9)	
B00D - R0011 - Movement - (71.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Canteen - (29.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Communal Space - (133.06 SQM)	Student Space (61)	
B00F - R0012 - Raised Platform - (48.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Movement - (56.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (133.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Practical Activities - 1hb - (19.45 SQM)	Student Space (9)	
B00G - R0005 - Home Base - (58.3 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Withdrawal Space - 1hb - (11.75 SQM)	Student Space (5)	
B00G - R0008 - Home Base - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0010 - Practical Activities - 1hb - (19.49 SQM)	Student Space (9)	
B00G - R0013 - Practical Activities - 1hb - (19.55 SQM)	Student Space (9)	
B00G - R0016 - Home Base - (58.3 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0017 - Withdrawal Space - 1hb - (11.68 SQM)	Student Space (5)	
B00G - R0018 - Home Base - (58.08 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0020 - Practical Activities - 1hb - (19.6 SQM)	 Student Space (9)	
B00H - R0001 - Movement - (59.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (18.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Withdrawal Space - 1hb - (33.07 SQM)	 Student Space (15)	
B00H - R0004 - Special Programs Room - (56.59 SQM)	 Student Space (26)	
B00H - R0005 - Practical Activities - 1hb - (20.26 SQM)	 Student Space (9)	
B00H - R0007 - Home Base - (56.35 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0008 - Practical Activities - 1hb - (14.35 SQM)	 Student Space (6)	
B00H - R0010 - Withdrawal Space - 1hb - (16.84 SQM)	 Student Space (7)	
B00H - R0012 - Movement - (11.8 SQM)	Not Applicable	Circulation or storage space.
OS 602 11775 - OS 602 11775 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 13823 - OS 606 13823 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	