


VENTILATION AUDIT REPORT

SCHOOL:	Wollongong High School of the Performing Arts (8143)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

8143 - Wollongong High School of the Performing Arts
Site Plan (13205)



1:3,260

Printed: 28-Aug-2021












Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Gymnasium - (288.91 SQM)	● Student Space (134)	
B00A - R0013 - Staff Study - (24.36 SQM)	● Office (6)	
B00A - R0016 - Movement - (81.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Study - (13.17 SQM)	● Office (3)	
B00B - R0002 - Staff Study - (10.97 SQM)	● Office (2)	
B00B - R0003 - Principal Office - (22.62 SQM)	● Office (5)	
B00B - R0004 - Administration - Clerical - (12.74 SQM)	● Office (3)	
B00B - R0007 - Clinic-Waiting - (14.42 SQM)	● Office (3)	
B00B - R0010 - Ancillary Staff - (29.43 SQM)	● Office (7)	
B00B - R0015 - Duplicating Workroom - (40.15 SQM)	● Office (10)	
B00B - R0016 - Administration - Clerical - (36.96 SQM)	● Office (9)	
B00B - R0019 - Multi-Purpose Space - (9.38 SQM)	● Student Space (4)	
B00B - R0020 - Deputy Principal Office - (16.6 SQM)	● Office (4)	
B00B - R0021 - Movement - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - General Learning Space - (52.46 SQM)	● Student Space (24)	
B00B - R0025 - General Learning Space - (52.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0026 - General Learning Space - (52.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0027 - General Learning Space - (52.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0031 - General Learning Space - (53.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0032 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0033 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0034 - General Learning Space - (65.37 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0035 - General Learning Space - (51.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0037 - Laboratory L.S. - (89.81 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0038 - Movement - (51.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0039 - Movement - (249.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Pupil Entry - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (89.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Movement - (42.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Staff Study - (38.72 SQM)	● Office (9)	
B00B - R1006 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - Computer Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1009 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1010 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1011 - General Learning Space - (52.71 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1012 - General Learning Space - (52.71 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1014 - Movement - (175.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Staff Study - (14.59 SQM)	● Office (3)	
B00B - R1020 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1021 - Preparation - (15.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Laboratory L.S. - (89.67 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R1023 - Movement - (50.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R1030 - Commonroom - (137.41 SQM)	● Office (34)	
B00B - R1031 - Staff Kitchen - (8.08 SQM)	● Office (2)	
B00B - R1032 - Staff Study - (52.59 SQM)	● Office (13)	
B00C - R0003 - Movement - (100.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Study - (23.04 SQM)	● Office (5)	
B00C - R0006 - Movement - (23.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Art Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0008 - Art Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - Art Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0015 - Pupil Entry - (15.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (16.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Staff Study - (26.17 SQM)	● Office (6)	
B00C - R1005 - Music Learning Space - (58.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1006 - Computer Learning Space - (39.43 SQM) - Teaching Space: 1	● Student Space (18)	
B00C - R1009 - Music Learning Space - (78.85 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1011 - Movement - (17.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R1014 - Movement - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R1015 - Movement - (70.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R1030 - Practice/Seminar - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R1033 - Practice/Seminar - (15.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Design L.S. - (70.1 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0003 - Design L.S. - (70.28 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0004 - Food Technology L.S. - (105.07 SQM) - Teaching Space: 1	● Student Space (48)	
B00D - R0005 - Food/Research Space - (17.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Food Technology L.S. - (104.37 SQM) - Teaching Space: 1	● Student Space (48)	
B00D - R0009 - Staff Study - (23.9 SQM)	● Office (5)	
B00D - R0016 - Movement - (69.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (81.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Staff Study - (31.54 SQM)	● Office (7)	
B00D - R1001 - Main Area - (340.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Workroom - (28.04 SQM)	● Office (7)	
B00D - R1003 - Audio Visual Workroom - (28.55 SQM)	● Student Space (13)	
B00D - R1006 - Seminar - (10.87 SQM)	● Office (2)	
B00D - R1007 - Seminar - (10.79 SQM)	● Office (2)	
B00D - R1014 - Movement - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Movement - (44.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (36.49 SQM)	● Office (9)	
B00E - R0013 - Study Space - (25.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Design L.S. - (56.29 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0016 - Darkroom Space - (7.87 SQM)	● Office (1)	
B00E - R0018 - Design L.S. - (67.49 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0019 - Materials Technology L.S. - (106.11 SQM) - Teaching Space: 1	● Student Space (49)	
B00E - R0020 - Wood Technology Bay - (19.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Materials Technology L.S. - (103.9 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R0023 - Movement - (86.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (46.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Performance Workspace - (105.46 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R0028 - Materials Technology L.S. - (87.62 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0029 - Metal Technology Bay - (38.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Multi-Purpose Space - (388.85 SQM)	● Student Space (180)	
B00F - R0005 - Stage - (92.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (78.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (10.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - General Learning Space - (70.45 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0003 - Student Canteen - (44.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Student Canteen - (5.13 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0006 - Movement - (259.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (83.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Staff Study - (26.27 SQM)	Office (6)	
B00G - R0011 - General Learning Space - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0012 - General Learning Space - (54.32 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0018 - General Learning Space - (54.39 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0021 - Movement - (31.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Staff Study - (27.38 SQM)	Office (6)	
B00G - R1011 - Movement - (96.88 SQM)	Not Applicable	Circulation or storage space.
B00G - R1012 - Staff Study - (13.39 SQM)	Office (3)	
B00G - R1013 - Staff Study - (20.06 SQM)	Office (5)	
B00G - R1014 - General Learning Space - (41.35 SQM) - Teaching Space: 1	Student Space (19)	
B00G - R1016 - General Learning Space - (40.44 SQM) - Teaching Space: 1	Student Space (18)	
B00G - R1019 - Withdrawal Space - 1hb - (26.34 SQM)	Student Space (12)	
B00G - R1022 - Movement - (65.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R1026 - General Learning Space - Type 10 - (48.17 SQM) - Teaching Space: 0.5	Student Space (22)	
B00G - R1027 - Science Laboratory - (42.08 SQM)	Student Space (19)	
B00G - R1028 - Preparation - Science - (35 SQM)	Not Applicable	Circulation or storage space.
B00G - R1029 - Science Laboratory - (38.93 SQM)	Student Space (18)	
B00G - R1030 - General Learning Space - Type 10 - (49.15 SQM) - Teaching Space: 0.5	Student Space (22)	
B00G - R1031 - Movement - (55.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R2001 - Performance Workspace - (70.79 SQM) - Teaching Space: 1	Student Space (32)	
B00G - R2002 - Movement - (14.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R2006 - Laboratory L.S. - (93.98 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R2008 - Preparation - (27.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R2009 - Laboratory L.S. - (93.52 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R2010 - Movement - (79.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R2011 - General Learning Space - (56.32 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R2012 - Staff Study - (25.45 SQM)	Office (6)	
B00G - R2014 - Commonroom - (8.86 SQM)	Office (2)	
B00G - R2017 - General Learning Space - (68.5 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R2018 - Movement - (65.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (16.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Administration - Clerical - (18.23 SQM)	Office (4)	
B00J - R0003 - Interview - (20.54 SQM)	Office (5)	
B00J - R0004 - Staff Kitchen - (13.67 SQM)	Office (3)	
B00J - R0008 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Staff Kitchen - (15.46 SQM)	Office (3)	
B00J - R0010 - Staff Study - (29.28 SQM)	Office (7)	
B00J - R0011 - Movement - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Public Reception - (16.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Withdrawal Space - 1hb - (24.58 SQM)	Student Space (11)	
B00M - R0001 - Movement Studio - (325.15 SQM)	Not Applicable	Circulation or storage space.
B00M - R0010 - Movement - (9.29 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Movement - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00M - R0023 - Performance Workshop - (132.22 SQM)	Student Space (61)	
NS 200 11955 - NS 200 11955 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 10527 - OS 600 10527 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 10530 - OS 600 10530 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 14448 - OS 600 14448 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 15491 - OS 600 15491 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 15922 - OS 600 15922 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 17961 - OS 600 17961 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 18342 - OS 600 18342 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19644 - OS 600 19644 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 19770 - OS 600 19770 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 10144 - OS 601 10144 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 10302 - OS 601 10302 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11926 - OS 601 11926 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12641 - OS 601 12641 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 780 19103 - OS 780 19103 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 904 14504 - OS 904 14504 - Dormitory (Toilet/Shower) - (190 SQM)	 Office (47)	