


VENTILATION AUDIT REPORT

SCHOOL:	Wongarbon Public School (3487)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

3487 - Wongarbon Public School
Site Plan (10811)




















1:817

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Movement - (9.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Reading Area - (95.14 SQM)	 Student Space (44)	
B00B - R0002 - Home Base - (60.75 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0003 - Practical Activities - 1hb - (15.89 SQM)	 Student Space (7)	
B00B - R0005 - Practical Activities - 1hb - (15.85 SQM)	 Student Space (7)	
B00B - R0006 - Home Base - (60.57 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0009 - Withdrawal Space - 1hb - (11.81 SQM)	 Student Space (5)	
B00E - R0002 - Principal - (17.04 SQM)	 Office (4)	
B00E - R0003 - Staff Room - (15.24 SQM)	 Office (3)	
B00E - R0004 - Duplicating Workroom - (13.13 SQM)	 Office (3)	
B00E - R0008 - Entry Vestibule - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Staff Kitchen - (12.12 SQM)	 Office (3)	
B00E - R0010 - Clerical Office/Workroom - (19.17 SQM)	 Office (4)	
B00E - R0011 - Interview/Meeting - (14.27 SQM)	 Office (3)	
B00G - R0002 - Practical Activities - 1hb - (21.61 SQM)	 Student Space (10)	
B00G - R0004 - Home Base - (63.34 SQM) - Teaching Space: 1	 Student Space (29)	
B00G - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	 Student Space (5)	
B00G - R0006 - Home Base - (63.34 SQM) - Teaching Space: 1	 Student Space (29)	
B00G - R0008 - Practical Activities - 1hb - (21.61 SQM)	 Student Space (10)	