


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woodberry Learning Centre (5764)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Maitland</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Maitland</b>

5764 - Woodberry Learning Centre  
Site Plan (11409)















1:966

Printed: 23-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Interview - (12.86 SQM)	 Office (3)	
B00A - R0003 - Principal - (12.86 SQM)	 Office (3)	
B00A - R0006 - Staff Room Annexe - (10.41 SQM)	 Office (2)	
B00A - R0007 - Staff Room - (20.41 SQM)	 Office (5)	
B00A - R0010 - Sick Bay - (6.63 SQM)	 Student Space (3)	
B00A - R0011 - Clerical Office/Workroom - (16.4 SQM)	 Office (4)	
B00A - R0012 - Movement - (20.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (58.44 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0004 - Home Base - (58.37 SQM) - Teaching Space: 1	 Student Space (27)	
B00C - R0001 - Home Base/Practical Activities - (41.1 SQM) - Teaching Space: 1	 Student Space (19)	
B00C - R0004 - Home Base - (60.37 SQM) - Teaching Space: 1	 Student Space (28)	
B00D - R0002 - Home Base - Bd/Cd/Ed - (36.6 SQM) - Teaching Space: 1	 Student Space (16)	
B00D - R0003 - Home Base - Bd/Cd/Ed - (36.6 SQM) - Teaching Space: 1	 Student Space (16)	