

VENTILATION AUDIT REPORT

SCHOOL:	Woodberry Public School (4459)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Maitland
LOCAL GOVERNMENT AREA:	Maitland









4459 - Woodberry Public School
Site Plan (11409)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Interview - (12.94 SQM)	 Office (3)	
B00A - R0007 - Movement - (15.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Staff Room - (76.08 SQM)	 Office (19)	
B00A - R0010 - Movement - (27.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Sick Bay - (17.44 SQM)	 Student Space (8)	
B00A - R0013 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room Annexe - (13.86 SQM)	 Office (3)	
B00A - R0015 - Staff Room Annexe - (12.68 SQM)	 Office (3)	
B00A - R0019 - Principal - (15.03 SQM)	 Office (3)	
B00A - R0020 - Principal - (9.21 SQM)	 Office (2)	
B00A - R0021 - Entry Vestibule - (23.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Clerical Office - (10.67 SQM)	 Office (2)	
B00A - R0024 - Duplicating Workroom - (18.62 SQM)	 Office (4)	
B00A - R1002 - Reading Area - (182.11 SQM)	 Student Space (84)	
B00A - R1003 - Home Base - (50.88 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R1008 - Movement - (16.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (16.64 SQM)	 Student Space (7)	
B00B - R0007 - Home Base - (85.41 SQM) - Teaching Space: 1	 Student Space (39)	
B00B - R0008 - Practical Activities - 1hb - (16.7 SQM)	 Student Space (7)	
B00B - R0011 - Darkroom Space - (8.56 SQM)	 Office (2)	
B00B - R0016 - Practical Activities - 1hb - (16.77 SQM)	 Student Space (7)	
B00B - R0018 - Home Base - (86.15 SQM) - Teaching Space: 1	 Student Space (39)	
B00B - R0019 - Home Base - (85.61 SQM) - Teaching Space: 1	 Student Space (39)	
B00B - R0020 - Practical Activities - 1hb - (16.83 SQM)	 Student Space (7)	
B00B - R0023 - Home Base - (74.91 SQM) - Teaching Space: 1	 Student Space (34)	
B00C - R0006 - Canteen - (31.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (16.7 SQM)	 Student Space (7)	
B00D - R0003 - Home Base - (54.05 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0004 - Home Base - (53.83 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0005 - Practical Activities - 1hb - (16.37 SQM)	 Student Space (7)	
B00D - R0009 - Practical Activities - 1hb - (16.88 SQM)	 Student Space (7)	
B00D - R0010 - Home Base - (54.61 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R0011 - Home Base - (53.42 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0012 - Practical Activities - 1hb - (20.57 SQM)	 Student Space (9)	
B00D - R1002 - Practical Activities - 1hb - (16.38 SQM)	 Student Space (7)	
B00D - R1003 - Home Base - (53.9 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1004 - Home Base - (54.18 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1005 - Practical Activities - 1hb - (15.94 SQM)	 Student Space (7)	
B00D - R1009 - Practical Activities - 1hb - (16.85 SQM)	 Student Space (7)	
B00D - R1010 - Home Base - (54.57 SQM) - Teaching Space: 1	 Student Space (25)	
B00D - R1011 - Home Base - (53.11 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R1012 - Practical Activities - 1hb - (20.51 SQM)	 Student Space (9)	
B00E - R0002 - Practical Activities - 1hb - (21.45 SQM)	 Student Space (9)	
B00E - R0005 - Practical Activities - 1hb - (21.42 SQM)	 Student Space (9)	
B00E - R0017 - Home Base - (106.54 SQM) - Teaching Space: 1	 Student Space (49)	
B00E - R1002 - Practical Activities - 1hb - (21.5 SQM)	 Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1003 - Home Base - (52.85 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1004 - Home Base - (53.17 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1005 - Practical Activities - 1hb - (21.49 SQM)	 Student Space (9)	
B00E - R1011 - Practical Activities - 1hb - (21.55 SQM)	 Student Space (9)	
B00E - R1012 - Home Base - (52.87 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1013 - Home Base - (52.77 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1014 - Practical Activities - 1hb - (21.33 SQM)	 Student Space (9)	
B00F - R0001 - Communal Space - (221.3 SQM)	 Student Space (102)	
B00F - R0002 - Raised Platform - (43.04 SQM)	Not Applicable	Circulation or storage space.