

VENTILATION AUDIT REPORT

SCHOOL:	Woodburn Public School (3490)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Richmond Valley

3490 - Woodburn Public School
Site Plan (11465)



1:836

Printed: 05-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0012 - Home Base - (55.58 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0013 - Practical Activities - 1hb - (20.71 SQM)	● Student Space (9)	
B00B - R0014 - Practical Activities - 1hb - (17.09 SQM)	● Student Space (7)	
B00B - R0015 - Home Base - (55.12 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0016 - Withdrawal Space - 2hb - (10.75 SQM)	● Student Space (4)	
B00B - R0020 - Home Base - (51.02 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0021 - Practical Activities - 1hb - (15.73 SQM)	● Student Space (7)	
B00B - R9008 - Movement - (14.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Practical Activities - 1hb - (18.03 SQM)	● Student Space (8)	
B00C - R0008 - Home Base - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0011 - Withdrawal Space - 2hb - (13.24 SQM)	● Student Space (6)	
B00C - R0012 - Home Base - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - Practical Activities - 1hb - (18.01 SQM)	● Student Space (8)	
B00E - R0002 - Practical Activities - 1hb - (9.3 SQM)	● Student Space (4)	
B00E - R0003 - Home Base - (51.46 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0004 - Staff Room Annexe - (7.89 SQM)	○ Office (1)	
B00E - R0005 - Home Base - (52.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Practical Activities - 1hb - (9.62 SQM)	● Student Space (4)	
B00G - R0007 - Home Base - (56.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Withdrawal Space - 2hb - (11.99 SQM)	● Student Space (5)	
B00G - R0009 - Home Base - (57.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0011 - Practical Activities - 1hb - (15.08 SQM)	● Student Space (6)	
B00G - R0012 - Practical Activities - 1hb - (15.38 SQM)	● Student Space (7)	
B00I - R0002 - Reading Area - (50.78 SQM)	● Student Space (23)	
B00I - R0003 - Reading Area - (68.84 SQM)	● Student Space (31)	
B00I - R0005 - Seminar/Study - (8.3 SQM)	○ Office (2)	
B00J - R0005 - Withdrawal Space - 1hb - (9.05 SQM)	● Student Space (4)	
B00J - R0010 - Home Base - (61.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0011 - Practical Activities - 1hb - (32.61 SQM)	● Student Space (15)	
B00Q - R0001 - Entry Vestibule - (24.37 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Duplicating Workroom - (19.8 SQM)	○ Office (4)	
B00Q - R0005 - Deputy Principal - (12.06 SQM)	○ Office (3)	
B00Q - R0009 - Staff Room Annexe - (20.45 SQM)	○ Office (5)	
B00Q - R0011 - Deputy Principal - (13.15 SQM)	○ Office (3)	
B00Q - R0012 - Principal - (18.83 SQM)	○ Office (4)	
B00Q - R0013 - Deputy Principal - (13.19 SQM)	○ Office (3)	
B00Q - R0015 - Sick Bay - (8.32 SQM)	● Student Space (3)	
B00Q - R0016 - Clerical Office - (17.67 SQM)	○ Office (4)	
B00Q - R0017 - Movement - (37.11 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0027 - Staff Kitchen - (6.66 SQM)	○ Office (1)	
B00Q - R0028 - Staff Room - (37.68 SQM)	○ Office (9)	
B00R - R0006 - Movement - (9.98 SQM)	Not Applicable	Circulation or storage space.
B00R - R0007 - Raised Platform - (59.2 SQM)	Not Applicable	Circulation or storage space.
B00R - R0008 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00R - R0011 - Canteen - (27.04 SQM)	Not Applicable	Circulation or storage space.
B00R - R0013 - Communal Space - (140.31 SQM)	● Student Space (65)	