

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woodport Public School (1857)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Terrigal</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

1857 - Woodport Public School  
Site Plan (12507)



1:926

Printed: 23-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (74.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (14.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Deputy Principal - (13.2 SQM)	Office (3)	
B00A - R0004 - Principal - (20.6 SQM)	Office (5)	
B00A - R0010 - Interview - (12.19 SQM)	Office (3)	
B00A - R0015 - Duplicating Workroom - (21.05 SQM)	Office (5)	
B00A - R0016 - Interview - (11.58 SQM)	Office (2)	
B00A - R0020 - Movement - (30.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (20.44 SQM)	Office (5)	
B00A - R0022 - Clerical Office - (9.81 SQM)	Office (2)	
B00A - R0024 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Room - (69.37 SQM)	Office (17)	
B00A - R0026 - Staff Kitchen - (8.71 SQM)	Office (2)	
B00B - R0001 - Movement - (51.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Reading Area - (154.47 SQM)	Student Space (71)	
B00B - R0009 - Seminar/Study - (10.88 SQM)	Office (2)	
B00B - R0010 - Seminar/Study - (11.08 SQM)	Office (2)	
B00C - R0001 - Withdrawal Space - 1hb - (8.5 SQM)	Student Space (3)	
B00C - R0002 - Practical Activities - 1hb - (22.75 SQM)	Student Space (10)	
B00C - R0004 - Movement - (22.87 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (49.87 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0006 - Movement - (25.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Withdrawal Space - 1hb - (5.8 SQM)	Student Space (2)	
B00L - R0002 - Home Base - (63.07 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0004 - Practical Activities - 1hb - (17.61 SQM)	Student Space (8)	
B00L - R0007 - Home Base - (63.07 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0008 - Practical Activities - 1hb - (17.6 SQM)	Student Space (8)	
B00L - R0009 - Withdrawal Space - 1hb - (8.72 SQM)	Student Space (4)	
B00L - R0010 - Home Base - (63.06 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0011 - Practical Activities - 1hb - (17.61 SQM)	Student Space (8)	
B00L - R0013 - Practical Activities - 1hb - (17.61 SQM)	Student Space (8)	
B00L - R0015 - Home Base - (63.06 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0016 - Withdrawal Space - 1hb - (8.72 SQM)	Student Space (4)	
B00L - R0017 - Home Base - (63.06 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R0019 - Practical Activities - 1hb - (17.6 SQM)	Student Space (8)	
B00L - R0022 - Movement - (86.02 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Withdrawal Space - 1hb - (5.8 SQM)	Student Space (2)	
B00L - R1002 - Home Base - (63.07 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R1003 - Practical Activities - 1hb - (17.61 SQM)	Student Space (8)	
B00L - R1005 - Practical Activities - 1hb - (17.62 SQM)	Student Space (8)	
B00L - R1007 - Home Base - (63.07 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R1008 - Withdrawal Space - 1hb - (8.72 SQM)	Student Space (4)	
B00L - R1009 - Home Base - (63.07 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R1011 - Practical Activities - 1hb - (17.62 SQM)	Student Space (8)	
B00L - R1014 - Practical Activities - 1hb - (17.61 SQM)	Student Space (8)	
B00L - R1016 - Home Base - (63.08 SQM) - Teaching Space: 1	Student Space (29)	
B00L - R1017 - Withdrawal Space - 1hb - (8.72 SQM)	Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1018 - Home Base - (63.07 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R1020 - Practical Activities - 1hb - (17.62 SQM)	● Student Space (8)	
B00L - R1024 - Movement - (84.56 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Canteen - (46.23 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (15.42 SQM)	Not Applicable	Circulation or storage space.
B00O - R0004 - Special Programs Room - (47.9 SQM)	● Student Space (22)	
B00O - R0006 - Movement - (27.82 SQM)	Not Applicable	Circulation or storage space.
B00O - R0007 - Movement - (60.02 SQM)	Not Applicable	Circulation or storage space.
B00O - R0008 - Communal Space - (208.35 SQM)	● Student Space (96)	
B00O - R0009 - Raised Platform - (37.65 SQM)	Not Applicable	Circulation or storage space.
B00O - R9005 - Movement - (47.02 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Practical Activities - 1hb - (21.46 SQM)	● Student Space (9)	
B00S - R0002 - Home Base - (55.15 SQM) - Teaching Space: 1	● Student Space (25)	
B00S - R0003 - Withdrawal Space - 1hb - (12.04 SQM)	● Student Space (5)	
B00S - R0007 - Home Base - (55.15 SQM) - Teaching Space: 1	● Student Space (25)	
B00S - R0008 - Practical Activities - 1hb - (21.46 SQM)	● Student Space (9)	
B00S - R0009 - Practical Activities - 1hb - (21.46 SQM)	● Student Space (9)	
B00S - R0010 - Home Base - (55.15 SQM) - Teaching Space: 1	● Student Space (25)	
B00S - R0011 - Withdrawal Space - 1hb - (5.49 SQM)	● Student Space (2)	
B00S - R0014 - Movement - (68.52 SQM)	Not Applicable	Circulation or storage space.
B00S - R0015 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Practical Activities - 1hb - (14.06 SQM)	● Student Space (6)	
B00T - R0004 - Home Base - (61.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00T - R0005 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00T - R0006 - Practical Activities - 1hb - (14.11 SQM)	● Student Space (6)	
B00T - R0009 - Home Base - (61.07 SQM) - Teaching Space: 1	● Student Space (28)	
B00V - R0001 - Practical Activities - 1hb - (14.27 SQM)	● Student Space (6)	
B00V - R0004 - Home Base - (61.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00V - R0005 - Withdrawal Space - 2hb - (11.57 SQM)	● Student Space (5)	
B00V - R0006 - Practical Activities - 1hb - (14.01 SQM)	● Student Space (6)	
B00V - R0009 - Home Base - (61.04 SQM) - Teaching Space: 1	● Student Space (28)	
B00X - R0001 - Outdoor Learning Area - (15.36 SQM)	Not Applicable	Circulation or storage space.