


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woollahra Public School (7442)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Vaucluse</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Woollahra</b>

7442 - Woollahra Public School  
Site Plan (11928)




























1:538

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0002 - Staff Room Annexe - (10.26 SQM)	Office (2)	
B00A - R0009 - Movement - (61.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office/Workroom - (10.64 SQM)	Office (2)	
B00A - R0013 - Home Base - (75.51 SQM) - Teaching Space: 1	Student Space (35)	
B00A - R0015 - Staff Room - (82.66 SQM)	Office (20)	
B00A - R0022 - Staff Room Annexe - (11.59 SQM)	Office (2)	
B00A - R0023 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Home Base - (64.68 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0035 - Practical Activities - 1hb - (20.2 SQM)	Student Space (9)	
B00A - R0036 - Withdrawal Space - 1hb - (8.79 SQM)	Student Space (4)	
B00A - R0039 - Special Programs Room - (19.14 SQM)	Student Space (8)	
B00A - R0041 - Movement - (14.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Movement - (7.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Movement - (12.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Clerical Office - (53.45 SQM)	Office (13)	
B00A - R0049 - Sick Bay - (8.35 SQM)	Student Space (3)	
B00A - R0051 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Deputy Principal - Type 1 - (21.13 SQM)	Office (5)	
B00A - R0053 - Principal - (22.86 SQM)	Office (5)	
B00A - R0054 - Deputy Principal - Type 1 - (15.62 SQM)	Office (3)	
B00A - R0055 - Home Base - (41.3 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0056 - Home Base/Practical Activities - (34.58 SQM) - Teaching Space: 1	Student Space (16)	
B00A - R0057 - Home Base - (45.69 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0058 - Home Base - (46.01 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0059 - Duplicating Workroom - (22.92 SQM)	Office (5)	
B00A - R1001 - Movement - (73.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (46.25 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1003 - Home Base - (47.6 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - Practical Activities - 1hb - (11.65 SQM)	Student Space (5)	
B00A - R1011 - Movement - (25.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Home Base - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1015 - Home Base - (46.4 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1016 - Home Base - (85.66 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R1017 - Withdrawal Space - 1hb - (15.27 SQM)	Student Space (7)	
B00A - R1019 - Home Base - (50.99 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1020 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Clerical Office - (14.09 SQM)	Office (3)	
B00B - R0007 - Home Base - (54.76 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0008 - Practical Activities - 1hb - (17.58 SQM)	Student Space (8)	
B00B - R0009 - Special Programs Room - (33.18 SQM)	Student Space (15)	
B00B - R0010 - Movement - (55.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Home Base - (54.17 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0013 - Movement - (49.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Practical Activities - 1hb - (13.25 SQM)	Student Space (6)	
B00B - R0020 - Home Base - (43.44 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0021 - Home Base - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0027 - Withdrawal Space - 1hb - (39.63 SQM)	Student Space (18)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1002 - Staff Room Annexe - (13.69 SQM)	 Office (3)	
B00B - R1006 - Movement - (39.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Movement - (11.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Home Base - (52.89 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R1014 - Home Base - (54.18 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R1015 - Home Base - (56.29 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R1019 - Staff Room - (18.98 SQM)	 Office (4)	
B00B - R1020 - Reading Area - (102.71 SQM)	 Student Space (47)	
B00B - R1021 - Duplicating Workroom - (12.69 SQM)	 Office (3)	
B00C - R0001 - Home Base - (56.78 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0006 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (56.79 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R0010 - Home Base - (53.53 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0011 - Home Base - (41.6 SQM) - Teaching Space: 1	 Student Space (19)	
B00E - R0012 - Practical Activities - (14.74 SQM)	 Student Space (6)	
B00E - R1001 - Home Base - (49.08 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1002 - Home Base - (48.4 SQM) - Teaching Space: 1	 Student Space (22)	
B00E - R1004 - Movement - (16.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Raised Platform - (81.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Communal Space - (188.55 SQM)	 Student Space (87)	
B00F - R0014 - Movement - (15.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0027 - Canteen - (43.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Practical Activities - 1hb - (20.19 SQM)	 Student Space (9)	
B00F - R1002 - Withdrawal Space - 2hb - (11.53 SQM)	 Student Space (5)	
B00F - R1004 - Home Base - (63.68 SQM) - Teaching Space: 1	 Student Space (29)	
B00F - R1005 - Practical Activities - 1hb - (18.63 SQM)	 Student Space (8)	
B00F - R1007 - Home Base - (60.43 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R1008 - Withdrawal Space - 1hb - (8.75 SQM)	 Student Space (4)	
B00F - R1010 - Practical Activities - 1hb - (20.84 SQM)	 Student Space (9)	
B00F - R1011 - Home Base - (57.08 SQM) - Teaching Space: 1	 Student Space (26)	
OS 600 14997 - OS 600 14997 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 14096 - OS 601 14096 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	