

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woonona East Public School (4296)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Keira</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollongong</b>

4296 - Woonona East Public School  
Site Plan (11410)




















1:1,019

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (58.91 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0004 - Movement - (18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (58.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0007 - Movement - (7.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (9.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Seminar/Study - (10.98 SQM)	 Office (2)	
B00B - R0005 - Home Base - (58 SQM) - Teaching Space: 1	 Student Space (26)	
B00B - R0011 - Home Base - (87.49 SQM) - Teaching Space: 1	 Student Space (40)	
B00B - R0012 - Home Base - (58.64 SQM) - Teaching Space: 1	 Student Space (27)	
B00B - R0016 - Movement - (33.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (19.4 SQM)	 Student Space (9)	
B00C - R0004 - Home Base - (59.21 SQM) - Teaching Space: 1	 Student Space (27)	
B00C - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00C - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00C - R0008 - Practical Activities - 1hb - (19.41 SQM)	 Student Space (9)	
B00D - R0003 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (11.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Movement - (55.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (56.98 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R0007 - Home Base - (60.05 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0001 - Canteen - (17.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (15.93 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (11.33 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Movement - (7.5 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (8.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Special Programs Room - (51.01 SQM)	 Student Space (23)	
B00I - R0009 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (148.61 SQM)	 Student Space (68)	
B00J - R0002 - Raised Platform - (57.67 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Movement - (13.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Canteen - (26.53 SQM)	Not Applicable	Circulation or storage space.
NS 020 15236 - NS 020 15236 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
OS 502 11224 - OS 502 11224 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 534 13575 - OS 534 13575 - Library/Group Study/Office/A V Store - (152 SQM)	 Student Space (70)	