


VENTILATION AUDIT REPORT

SCHOOL:	Woonona High School (8410)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

8410 - Woonona High School
Site Plan (12917)



1:1,920

Printed: 05-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Staff Study - (24.2 SQM)	Office (6)	
B00A - R0008 - Laboratory L.S. - (86.12 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0010 - Preparation - (27.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Laboratory L.S. - (86.41 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0012 - Darkroom Space - (23.84 SQM)	Office (5)	
B00A - R0024 - Laboratory L.S. - (87.76 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0026 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (45.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Staff Study - (24.2 SQM)	Office (6)	
B00A - R1011 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - General Learning Space - (65.57 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1025 - Movement - (43.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R9002 - Movement - (11.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Student Canteen - (43.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (303.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (32.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (33.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (17.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Materials Technology L.S. - (79.66 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0008 - Materials Technology L.S. - (81.46 SQM)	Student Space (37)	
B00C - R0009 - Movement - (13.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Welding Area - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (19.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Art Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - Art Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1005 - Art Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1009 - Staff Study - (25.55 SQM)	Office (6)	
B00C - R1010 - Movement - (21.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Study - (18.09 SQM)	Office (4)	
B00D - R0007 - Principal Office - (18.2 SQM)	Office (4)	
B00D - R0011 - Deputy Principal Office - (18.1 SQM)	Office (4)	
B00D - R0015 - Duplicating Workroom - (22.88 SQM)	Office (5)	
B00D - R0016 - Administration - Clerical - (13.48 SQM)	Office (3)	
B00D - R0017 - Interview/Office - Type 1 - (13.76 SQM)	Office (3)	
B00D - R0021 - Movement - (35.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Public Entry - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Interview/Meeting - (10.74 SQM)	Office (2)	
B00D - R0031 - Administration - Clerical - (39.16 SQM)	Office (9)	
B00D - R0032 - Student Reception - (12.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Interview/Meeting - (8.95 SQM)	Office (2)	
B00D - R0034 - Deputy Principal Office - (18 SQM)	Office (4)	
B00D - R0035 - Interview/Meeting - (13.2 SQM)	Office (3)	
B00D - R0037 - Interview/Meeting - (33.87 SQM)	Office (8)	
B00D - R0038 - Movement - (34.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (17.78 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0012 - Staff Study - (25.92 SQM)	Office (6)	
B00E - R0013 - Staff Study - (25.4 SQM)	Office (6)	
B00E - R0016 - Movement - (42.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Seminar - (12.81 SQM)	Office (3)	
B00E - R0019 - Seminar - (12.92 SQM)	Office (3)	
B00E - R0020 - Main Area - (241.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Entry - (7.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Audio Visual Workroom - (33.48 SQM)	Student Space (15)	
B00E - R0026 - Workroom - (25.92 SQM)	Office (6)	
B00E - R0033 - Movement - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Main Area - (373.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Interview/Office - Type 1 - (8.24 SQM)	Office (2)	
B00E - R0037 - Interview/Office - Type 1 - (8.22 SQM)	Office (2)	
B00E - R0038 - Staff Kitchen - (7.05 SQM)	Office (1)	
B00E - R0039 - Staff Kitchen - (5.76 SQM)	Office (1)	
B00E - R0040 - Study Space - (13.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0041 - Interview/Office - Type 1 - (14.24 SQM)	Office (3)	
B00E - R1001 - Movement - (21.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Music Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1006 - Music Learning Space - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1007 - Design L.S. - (65.3 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1014 - Movement - (14.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - Seminar - Type 1 - (22.26 SQM)	Office (5)	
B00E - R1020 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Computer Room - (5.65 SQM)	Student Space (2)	
B00E - R1022 - Commonroom - (118.52 SQM)	Office (29)	
B00G - R0001 - Movement - (28.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Laboratory L.S. - (82.75 SQM) - Teaching Space: 1	Student Space (38)	
B00G - R0013 - Food Technology L.S. - (89.38 SQM) - Teaching Space: 1	Student Space (41)	
B00G - R0014 - Food/Research Space - (9.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Food/Research Space - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (28.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Design L.S. - (65.45 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0028 - Design L.S. - (59.32 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0029 - General Assistants - (12.95 SQM)	Office (3)	
B00G - R1014 - Workroom - (15.96 SQM)	Office (3)	
B00G - R1017 - Staff Study - (12.56 SQM)	Office (3)	
B00G - R1018 - Staff Study - (21.63 SQM)	Office (5)	
B00G - R1019 - Staff Study - (8.27 SQM)	Office (2)	
B00G - R1020 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1025 - Movement - (20.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R1026 - Movement - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00G - R1027 - Art Learning Space - (66.3 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1028 - Art Learning Space - (55.76 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R1030 - General Learning Space - (52.86 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1031 - General Learning Space - (39.37 SQM)	Student Space (18)	
B00G - R1034 - Staff Study - (9.55 SQM)	Office (2)	
B00G - R1035 - Workshop - (12.56 SQM)	Student Space (5)	
B00G - R1036 - Workshop - (13 SQM)	Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1040 - General Learning Space - (79.58 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R1041 - Interview/Office - Type 1 - (15.71 SQM)	● Office (3)	
B00G - R1043 - Movement - (7.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R2004 - General Learning Space - (53 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2007 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2008 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2009 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2013 - General Learning Space - (53.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2014 - General Learning Space - (52.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2015 - General Learning Space - (53.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2016 - Staff Study - (21.12 SQM)	● Office (5)	
B00G - R2017 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R2018 - Staff Study - (26.53 SQM)	● Office (6)	
B00G - R2020 - Movement - (20.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R2021 - Movement - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R2025 - Staff Study - (11.29 SQM)	● Office (2)	
B00H - R0002 - Stage - (117.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (71.1 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Student Canteen - (18.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Multi-Purpose Space - (454.22 SQM)	● Student Space (210)	
B00H - R9001 - Gymnasium - (109.35 SQM)	● Student Space (50)	
B0F1 - R0001 - Movement - (19.96 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0004 - Staff Study - (25.44 SQM)	● Office (6)	
B0F1 - R0005 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R0006 - General Learning Space - (55.41 SQM) - Teaching Space: 1	● Student Space (25)	
B0F1 - R0009 - Laboratory L.S. - (91.67 SQM) - Teaching Space: 1	● Student Space (42)	
B0F1 - R0011 - Preparation - (28.21 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R0012 - Laboratory L.S. - (91.77 SQM) - Teaching Space: 1	● Student Space (42)	
B0F1 - R1001 - Movement - (20.48 SQM)	Not Applicable	Circulation or storage space.
B0F1 - R1004 - Staff Study - (25.22 SQM)	● Office (6)	
B0F1 - R1005 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R1006 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R1007 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R1011 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R1012 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B0F1 - R1013 - Computer Learning Space - (65.21 SQM) - Teaching Space: 1	● Student Space (30)	
B0F2 - R0001 - Movement - (20.74 SQM)	Not Applicable	Circulation or storage space.
B0F2 - R0006 - Materials Technology L.S. - (105.8 SQM) - Teaching Space: 1	● Student Space (49)	
B0F2 - R1001 - Movement - (19.73 SQM)	Not Applicable	Circulation or storage space.
B0F2 - R1005 - Staff Study - (10.53 SQM)	● Office (2)	
B0F2 - R1008 - Materials Technology L.S. - (94.1 SQM) - Teaching Space: 1	● Student Space (43)	
B0F3 - R0001 - Materials Technology L.S. - (91.43 SQM) - Teaching Space: 1	● Student Space (42)	
B0F3 - R0002 - Welding Area - (17.63 SQM)	Not Applicable	Circulation or storage space.
OS 606 19181 - OS 606 19181 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	