


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woronora River Public School (3735)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Heathcote</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

3735 - Woronora River Public School  
Site Plan (11472)



1:846

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (22.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Entry Vestibule - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Principal - (12.96 SQM)	Office (3)	
B00A - R0010 - Clerical Office - (19.42 SQM)	Office (4)	
B00A - R1001 - Movement - (38.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (56.71 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1004 - Staff Room - (19.71 SQM)	Office (4)	
B00A - R1008 - Duplicating Workroom - (6.15 SQM)	Office (1)	
B00A - R1009 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (42.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Communal Space - (98.48 SQM)	Student Space (45)	
B00B - R0003 - Home Base - (57.26 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1001 - Movement - (41.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Home Base - (84.19 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R1006 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R9001 - Movement - (16.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Home Base - (63.52 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R9003 - Practical Activities - 1hb - (7.15 SQM)	Student Space (3)	
B00C - R0001 - Movement - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (46.84 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0001 - Movement - (13.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Canteen - (15.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (11.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Special Programs Room - (52.41 SQM)	Student Space (24)	
B00I - R0001 - Reading Area - (90.4 SQM)	Student Space (41)	
B00I - R0006 - Canteen - (13.46 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R1003 - Practical Activities - 1hb - (19.08 SQM)	Student Space (8)	
B00I - R1004 - Withdrawal Space - 2hb - (12.38 SQM)	Student Space (5)	
B00I - R1005 - Practical Activities - 1hb - (18.76 SQM)	Student Space (8)	
B00I - R1006 - Home Base - (61.08 SQM) - Teaching Space: 1	Student Space (28)	