

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Woy Woy Public School (7445)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Gosford</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

7445 - Woy Woy Public School  
Site Plan (11570)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (14.29 SQM)	Office (3)	
B00A - R0003 - Duplicating Workroom - (19.19 SQM)	Office (4)	
B00A - R0004 - Interview - (13.58 SQM)	Office (3)	
B00A - R0005 - Principal - (16.88 SQM)	Office (4)	
B00A - R0006 - Entry Vestibule - (26.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (12.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room Annexe - (17.09 SQM)	Office (4)	
B00A - R0015 - Staff Room - (53.58 SQM)	Office (13)	
B00A - R0016 - Deputy Principal - (10.98 SQM)	Office (2)	
B00A - R0018 - Clerical Office - (18.11 SQM)	Office (4)	
B00A - R0020 - Sick Bay - (8.57 SQM)	Student Space (3)	
B00A - R0022 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (41.85 SQM) - Teaching Space: 1	Student Space (19)	
B00B - R0006 - Practical Activities - 1hb - (23.37 SQM)	Student Space (10)	
B00B - R0007 - Practical Activities - 1hb - (13.23 SQM)	Student Space (6)	
B00B - R0008 - Home Base - (47.28 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Home Base - (47.95 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0014 - Movement - (66.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Special Programs Room - (37.94 SQM)	Student Space (17)	
B00B - R0018 - Home Base - (50.43 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0019 - Home Base - (48.82 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0022 - Practical Activities - 1hb - (17.67 SQM)	Student Space (8)	
B00B - R0023 - Clerical Office - (57.11 SQM)	Office (14)	
B00B - R0024 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (34.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Reading Area - (146.84 SQM)	Student Space (68)	
B00B - R0029 - Reading Area - (47.26 SQM)	Student Space (21)	
B00B - R0032 - Movement - (72.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (5.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (23.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Canteen - (27.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Communal Space - (135.19 SQM)	Student Space (62)	
B00E - R0014 - Raised Platform - (54.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Movement - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (79.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (9.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (56.02 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0003 - Practical Activities - 1hb - (10.7 SQM)	Student Space (4)	
B00G - R0005 - Practical Activities - 1hb - (13.88 SQM)	Student Space (6)	
B00G - R0006 - Home Base - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0007 - Home Base - (53.54 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0008 - Practical Activities - 1hb - (14.94 SQM)	Student Space (6)	
B00G - R0010 - Home Base - (53.61 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0011 - Practical Activities - 1hb - (12.51 SQM)	Student Space (5)	
B00G - R0013 - Home Base - (54.85 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R0014 - Practical Activities - 1hb - (16.08 SQM)	Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0015 - Movement - (94.65 SQM)	Not Applicable	Circulation or storage space.
B00H - M0001 - Withdrawal - Pre - (12.89 SQM)	● Student Space (5)	
B00H - R0001 - Movement - (12.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Withdrawal - Pre - (15.01 SQM)	● Student Space (6)	
B00H - R0013 - Home Base - Pre - (89.22 SQM) - Teaching Space: 1	● Student Space (41)	
B00K - R0001 - Movement - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00K - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B00M - R0001 - Practical Activities - 1hb - (18.77 SQM)	● Student Space (8)	
B00M - R0003 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0004 - Withdrawal Space - 2hb - (11.56 SQM)	● Student Space (5)	
B00M - R0005 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00M - R0007 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0008 - Practical Activities - 1hb - (18.52 SQM)	● Student Space (8)	
B00M - R0010 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0011 - Withdrawal Space - 2hb - (11.56 SQM)	● Student Space (5)	
B00M - R0012 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00M - R0014 - Home Base - (60.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0001 - Practical Activities - M - 1hb - (19.14 SQM)	● Student Space (8)	
B00N - R0003 - Home Base - M - (60.79 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0004 - Withdrawal Space - 2hb - (11.57 SQM)	● Student Space (5)	
B00N - R0005 - Practical Activities - M - 1hb - (19.03 SQM)	● Student Space (8)	
B00N - R0007 - Home Base - M - (60.86 SQM) - Teaching Space: 1	● Student Space (28)	
NS 120 14754 - NS 120 14754 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
OS 534 13721 - OS 534 13721 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 10535 - OS 601 10535 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 15756 - OS 602 15756 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 11827 - OS 606 11827 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 622 17805 - OS 622 17805 - Single Learning Unit - Early Childhood - (76 SQM)	● Student Space (35)	