


VENTILATION AUDIT REPORT

SCHOOL:	Wye Public School (3522)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Lake Macquarie
LOCAL GOVERNMENT AREA:	Lake Macquarie

3522 - Wye Public School
Site Plan (10810)



1:805

Printed: 04-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (47.01 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0002 - Movement - (25.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Room Annexe - (14.06 SQM)	● Office (3)	
B00A - R0005 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Interview - (18.59 SQM)	● Office (4)	
B00B - R0001 - Special Programs Room - (53.22 SQM)	● Student Space (24)	
B00B - R0002 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (33.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0006 - Home Base - (56.56 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0008 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (26.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (56.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Movement - (8.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Staff Room - (25.02 SQM)	● Office (6)	
B00E - R0007 - Staff Room Annexe - (11.3 SQM)	● Office (2)	
B00E - R0008 - Duplicating Workroom - (17.58 SQM)	● Office (4)	
B00E - R0009 - Clerical Office/Workroom - (6.99 SQM)	● Office (1)	
B00E - R0010 - Principal - (15.02 SQM)	● Office (3)	
B00E - R0012 - Clerical Office - (21.36 SQM)	● Office (5)	
B00E - R0013 - Entry Vestibule - (15.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Sick Bay - (5.25 SQM)	● Student Space (2)	
B00E - R0016 - Clerical/Printing - (26.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Staff Room - (14.38 SQM)	● Office (3)	
B00E - R0018 - Staff Kitchen - (10.57 SQM)	● Office (2)	
B00G - R0001 - Movement - (36.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Canteen - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Movement - (5.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (74.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (18.16 SQM)	● Student Space (8)	
B00J - R0003 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0005 - Movement - (14.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0006 - Withdrawal Space - 1hb - (12.16 SQM)	● Student Space (5)	
B00J - R0007 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Home Base - (60.64 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0010 - Practical Activities - 1hb - (18.16 SQM)	● Student Space (8)	
B00J - R0011 - Practical Activities - 1hb - (18.16 SQM)	● Student Space (8)	
B00J - R0012 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0014 - Movement - (14.26 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Withdrawal Space - 1hb - (12.16 SQM)	● Student Space (5)	
B00J - R0016 - Movement - (14.17 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Home Base - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0019 - Practical Activities - 1hb - (18.12 SQM)	● Student Space (8)	
B00K - R0001 - Communal Space - (114.48 SQM)	● Student Space (53)	
B00L - R0001 - Reading Area - (90.52 SQM)	● Student Space (41)	
OS 602 10380 - OS 602 10380 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	