

VENTILATION AUDIT REPORT

SCHOOL:	Wyong Public School (3527)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wyong
LOCAL GOVERNMENT AREA:	Central Coast

3527 - Wyong Public School
Site Plan (10851)




































1:1,065

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (39.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Deputy Principal - (12.88 SQM)	Office (3)	
B00A - R0014 - Principal - (18.21 SQM)	Office (4)	
B00A - R0020 - Staff Room - (76.44 SQM)	Office (19)	
B00A - R0021 - Interview - (12.35 SQM)	Office (3)	
B00A - R0022 - Movement - (33.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Entry Vestibule - (20.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Interview - (13.66 SQM)	Office (3)	
B00A - R0026 - Principal - (20.08 SQM)	Office (5)	
B00A - R0027 - Deputy Principal - (14.21 SQM)	Office (3)	
B00A - R0028 - Clerical Office/Workroom - (64.87 SQM)	Office (16)	
B00A - R0029 - Movement - (35.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (129.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (5.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (34.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Special Programs Room - (45.37 SQM)	Student Space (21)	
B00B - R0034 - Reading Area - (219.72 SQM)	Student Space (101)	
B00B - R1001 - Movement - (72.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Movement - (31.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R1020 - Deputy Principal - (19.86 SQM)	Office (4)	
B00C - M0001 - Movement - (23.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (16.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Communal Space - (222.22 SQM)	Student Space (103)	
B00C - R0012 - Raised Platform - (66.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Canteen - (37.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (43.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (96.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00D - M1001 - Withdrawal Space - 1hb - (14.8 SQM)	Student Space (6)	
B00D - M1002 - Withdrawal Space - 1hb - (14.8 SQM)	Student Space (6)	
B00D - R0002 - Practical Activities - 1hb - (30.69 SQM)	Student Space (14)	
B00D - R0005 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0006 - Withdrawal Space - 1hb - (12.53 SQM)	Student Space (5)	
B00D - R0007 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Withdrawal Space - 1hb - (16.27 SQM)	Student Space (7)	
B00D - R0009 - Home Base - (60.87 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0010 - Withdrawal Space - 1hb - (12.53 SQM)	Student Space (5)	
B00D - R0011 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0014 - Movement - (32.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Practical Activities - 1hb - (52.83 SQM)	Student Space (24)	
B00D - R0018 - Movement - (57.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Practical Activities - 1hb - (52.83 SQM)	Student Space (24)	
B00D - R1004 - Movement - (35.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1007 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1008 - Staff Room Annexe - (16.27 SQM)	Office (4)	
B00D - R1009 - Home Base - (60.87 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1010 - Home Base - (60.86 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1013 - Movement - (27.79 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1014 - Practical Activities - 1hb - (50.64 SQM)	 Student Space (23)	
B00D - R1017 - Movement - (57.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Practical Activities - 1hb - (50.65 SQM)	 Student Space (23)	
B00E - M1001 - Withdrawal Space - 1hb - (14.8 SQM)	 Student Space (6)	
B00E - M1002 - Withdrawal Space - 1hb - (14.8 SQM)	 Student Space (6)	
B00E - R0001 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R0003 - Withdrawal Space - 1hb - (12.53 SQM)	 Student Space (5)	
B00E - R0004 - Home Base - (60.87 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R0005 - Staff Room Annexe - (16.27 SQM)	 Office (4)	
B00E - R0006 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R0007 - Withdrawal Space - 1hb - (12.53 SQM)	 Student Space (5)	
B00E - R0008 - Home Base - (60.88 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R0011 - Movement - (32.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Practical Activities - 1hb - (52.82 SQM)	 Student Space (24)	
B00E - R0015 - Movement - (57.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Practical Activities - 1hb - (52.83 SQM)	 Student Space (24)	
B00E - R1004 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R1011 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R1012 - Staff Room Annexe - (16.27 SQM)	 Office (4)	
B00E - R1013 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R1014 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00E - R1017 - Movement - (27.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R1018 - Practical Activities - 1hb - (50.63 SQM)	 Student Space (23)	
B00E - R1021 - Movement - (57.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - Practical Activities - 1hb - (50.63 SQM)	 Student Space (23)	
B00F - M0002 - Withdrawal Space - 1hb - (15.04 SQM)	 Student Space (6)	
B00F - R0001 - Movement - (49.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (59.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0005 - Home Base - (59.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0006 - Staff Room Annexe - (7.93 SQM)	 Office (1)	
B00F - R0009 - Staff Room Annexe - (12.01 SQM)	 Office (3)	
B00F - R0010 - Staff Room Annexe - (11.69 SQM)	 Office (2)	
B00F - R0011 - Home Base - (59.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0012 - Home Base - (59.95 SQM) - Teaching Space: 1	 Student Space (27)	
B00F - R0013 - Withdrawal Space - 1hb - (12.59 SQM)	 Student Space (5)	
B00F - R0015 - Home Base - (65.24 SQM) - Teaching Space: 1	 Student Space (30)	
B00F - R0019 - Practical Activities - 1hb - (67.09 SQM)	 Student Space (31)	
B00F - R0022 - Movement - (74.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Practical Activities - 1hb - (50.72 SQM)	 Student Space (23)	
OS 534 13471 - OS 534 13471 - Library/Group Study/Office/A V Store - (152 SQM)	 Student Space (70)	