


VENTILATION AUDIT REPORT

SCHOOL:	Yamba Public School (3533)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley

3533 - Yamba Public School
Site Plan (11642)









1:1,598

Printed: 17-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (17.94 SQM)	● Student Space (8)	
B00A - R0003 - Withdrawal Space - 1hb - (6.17 SQM)	● Student Space (2)	
B00A - R0004 - Home Base - (58.56 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Practical Activities - 1hb - (17.75 SQM)	● Student Space (8)	
B00A - R0007 - Home Base - (58.72 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0010 - Withdrawal Space - 1hb - (12.55 SQM)	● Student Space (5)	
B00A - R0012 - Practical Activities - 1hb - (17.7 SQM)	● Student Space (8)	
B00A - R0013 - Home Base - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0014 - Practical Activities - 1hb - (17.73 SQM)	● Student Space (8)	
B00A - R0015 - Home Base - (58.56 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0016 - Withdrawal Space - 1hb - (12.55 SQM)	● Student Space (5)	
B00A - R0020 - Practical Activities - 1hb - (17.51 SQM)	● Student Space (8)	
B00A - R0021 - Home Base - (58.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0022 - Practical Activities - 1hb - (21.55 SQM)	● Student Space (9)	
B00A - R0023 - Home Base - (58.33 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0024 - Withdrawal Space - 1hb - (6.16 SQM)	● Student Space (2)	
B00A - R0028 - Staff Room - (68.33 SQM)	● Office (17)	
B00A - R0029 - Duplicating Workroom - (21.15 SQM)	● Office (5)	
B00A - R0031 - Movement - (32.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Deputy Principal - (12.55 SQM)	● Office (3)	
B00A - R0034 - Principal - (12.54 SQM)	● Office (3)	
B00A - R0035 - Deputy Principal - (16.44 SQM)	● Office (4)	
B00A - R0038 - Sick Bay - (9.13 SQM)	● Student Space (4)	
B00A - R0039 - Clerical Office - (17.34 SQM)	● Office (4)	
B00A - R0040 - Interview - (12.86 SQM)	● Office (3)	
B00A - R0041 - Entry Vestibule - (18.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Withdrawal Space - 1hb - (5.85 SQM)	● Student Space (2)	
B00B - R0004 - Practical Activities - 1hb - (17.64 SQM)	● Student Space (8)	
B00B - R0005 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Practical Activities - 1hb - (17.63 SQM)	● Student Space (8)	
B00B - R0007 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0008 - Withdrawal Space - 1hb - (12.55 SQM)	● Student Space (5)	
B00B - R0012 - Practical Activities - 1hb - (17.64 SQM)	● Student Space (8)	
B00B - R0013 - Home Base - (57.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0014 - Practical Activities - 1hb - (17.62 SQM)	● Student Space (8)	
B00B - R0015 - Home Base - (57.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0016 - Withdrawal Space - 1hb - (6.31 SQM)	● Student Space (2)	
B00C - R0005 - Canteen - (26.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Raised Platform - (66.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Communal Space - (188.16 SQM)	● Student Space (87)	
B00D - R0003 - Reading Area - (162.48 SQM)	● Student Space (75)	
B00D - R0005 - Special Programs Room - (35.89 SQM)	● Student Space (16)	
B00G - R0005 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0006 - Practical Activities - 1hb - (20.3 SQM)	● Student Space (9)	
B00G - R0008 - Withdrawal Space - 1hb - (9.06 SQM)	● Student Space (4)	
B00G - R0010 - Home Base - (60.04 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0011 - Practical Activities - 1hb - (19.68 SQM)	 Student Space (9)	
B00G - R0012 - Withdrawal Space - 2hb - (11.77 SQM)	 Student Space (5)	
B00G - R0013 - Practical Activities - 1hb - (19.76 SQM)	 Student Space (9)	
B00G - R0014 - Home Base - (59.55 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0016 - Special Programs Room - (38.78 SQM)	 Student Space (17)	
OS 621 14493 - OS 621 14493 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	