

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Yandelora School (5766)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

5766 - Yandelora School  
Site Plan (14767)
























1:881

Printed: 23-Jan-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Breakout Area - (11.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (7.72 SQM)	Office (1)	
B00A - R0009 - Movement - (94.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Hydrotherapy - Pool - (78.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (117.53 SQM)	Student Space (54)	
B00C - R0001 - Reading Area - (151.32 SQM)	Student Space (70)	
B00C - R0003 - Staff Kitchen - (20.24 SQM)	Office (5)	
B00C - R0004 - Special Programs Room - (31.07 SQM)	Student Space (14)	
B00C - R0008 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Entry Vestibule - (17.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Interview - (11.41 SQM)	Office (2)	
B00D - R0003 - Interview - (11.98 SQM)	Office (2)	
B00D - R0004 - Principal - (16.75 SQM)	Office (4)	
B00D - R0008 - Movement - (23.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Staff Room - (71.14 SQM)	Office (17)	
B00D - R0017 - Movement - (61.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Interview - (12.63 SQM)	Office (3)	
B00D - R0019 - Deputy Principal - (12.84 SQM)	Office (3)	
B00D - R0020 - Sick Bay - (8.69 SQM)	Student Space (4)	
B00D - R0022 - Clerical Office - (52.1 SQM)	Office (13)	
B00D - R0027 - Staff Kitchen - (7.88 SQM)	Office (1)	
B00E - R0001 - Special Programs Room - Type 1 - (112.92 SQM)	Student Space (52)	
B00E - R0002 - Withdrawal Space - 1hb - (11.24 SQM)	Student Space (5)	
B00E - R0007 - Practical Activities - 3hb - (19.84 SQM)	Student Space (9)	
B00E - R0008 - Home Base - S - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Withdrawal Space - 2hb - (12 SQM)	Student Space (5)	
B00E - R0010 - Home Base - S - (59.25 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0011 - Home Base - S - (56.61 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0015 - Movement - (7.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Staff Kitchen - (8.81 SQM)	Office (2)	
B00F - R0001 - Special Programs Room - Type 1 - (114.62 SQM)	Student Space (53)	
B00F - R0002 - Withdrawal - S - (11.26 SQM)	Student Space (5)	
B00F - R0007 - Practical Activities - 3hb - (15.86 SQM)	Student Space (7)	
B00F - R0008 - Home Base - S - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0009 - Home Base - S - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0010 - Withdrawal - S - (11.1 SQM)	Student Space (5)	
B00F - R0011 - Home Base - S - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0014 - Staff Kitchen - (9.83 SQM)	Office (2)	
B00F - R0015 - Staff Kitchen - (8.59 SQM)	Office (2)	
B00G - R0001 - Special Programs Room - Type 1 - (108.03 SQM)	Student Space (50)	
B00G - R0002 - Withdrawal - S - (9.97 SQM)	Student Space (4)	
B00G - R0007 - Practical Activities - 3hb - (22.82 SQM)	Student Space (10)	
B00G - R0009 - Home Base - S - (57.07 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0010 - Withdrawal - S - (12 SQM)	Student Space (5)	
B00G - R0012 - Home Base - S - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0013 - Home Base - S - (57.91 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0016 - Staff Kitchen - (7.94 SQM)	 Office (1)	
B00H - R0001 - Special Programs Room - Type 1 - (57.77 SQM)	 Student Space (26)	
B00H - R0002 - Practical Activities - (11.93 SQM)	 Student Space (5)	
B00H - R0003 - Home Base - S - (53.13 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0004 - Withdrawal - S - (7.9 SQM)	 Student Space (3)	
B00H - R0008 - Withdrawal - S - (8.34 SQM)	 Student Space (3)	
B00H - R0009 - Home Base - S - (53.25 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0012 - Home Base - S - (53.19 SQM) - Teaching Space: 1	 Student Space (24)	
B00H - R0013 - Withdrawal - S - (8.28 SQM)	 Student Space (3)	
B00H - R0015 - Staff Kitchen - (5.23 SQM)	 Office (1)	
B00I - R0001 - Special Programs Room - Type 1 - (89.39 SQM)	 Student Space (41)	
B00I - R0002 - Home Base - S - (52.02 SQM) - Teaching Space: 1	 Student Space (24)	
B00I - R0003 - Home Base - S - (51.64 SQM) - Teaching Space: 1	 Student Space (23)	
B00I - R0004 - Home Base - S - (51.64 SQM) - Teaching Space: 1	 Student Space (23)	
B00I - R0005 - Home Base - S - (52.31 SQM) - Teaching Space: 1	 Student Space (24)	
B00I - R0007 - Withdrawal - S - (8.8 SQM)	 Student Space (4)	
B00I - R0009 - Withdrawal - S - (8.35 SQM)	 Student Space (3)	
B00I - R0012 - Withdrawal - S - (8.38 SQM)	 Student Space (3)	
B00I - R0014 - Withdrawal - S - (8.64 SQM)	 Student Space (4)	
B00I - R0017 - Practical Activities - 4hb - (14.96 SQM)	 Student Space (6)	
B00I - R0018 - Staff Kitchen - (5.1 SQM)	 Office (1)	