

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Yarrawarra Public School (4298)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Heathcote</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

4298 - Yarrawarra Public School  
Site Plan (11475)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (67.61 SQM)	Office (16)	
B00A - R0003 - Entry Vestibule - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office - (15.84 SQM)	Office (3)	
B00A - R0005 - Duplicating Workroom - (18.76 SQM)	Office (4)	
B00A - R0008 - Deputy Principal - (14.66 SQM)	Office (3)	
B00A - R0011 - Movement - (28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room Annexe - (11.54 SQM)	Office (2)	
B00A - R0014 - Sick Bay - (9.73 SQM)	Student Space (4)	
B00A - R0015 - Principal - (13.82 SQM)	Office (3)	
B00A - R0016 - Interview - (11.25 SQM)	Office (2)	
B00B - R0001 - Home Base - (56.48 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0006 - Home Base - (57.75 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0018 - Practical Activities - 1hb - (8.85 SQM)	Student Space (4)	
B00B - R0019 - Home Base - (77.76 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0020 - Home Base - (73.89 SQM) - Teaching Space: 1	Student Space (34)	
B00B - R0021 - Practical Activities - 1hb - (7.12 SQM)	Student Space (3)	
B00C - R0006 - Home Base - (56.87 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1001 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1006 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (56.89 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0006 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1005 - Special Programs Room - (59.05 SQM)	Student Space (27)	
B00D - R1006 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0002 - Practical Activities - 1hb - (17.02 SQM)	Student Space (7)	
B00E - R0003 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Outdoor Learning Area - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Withdrawal Space - 1hb - (11.82 SQM)	Student Space (5)	
B00E - R0007 - Outdoor Learning Area - (13.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Home Base - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Practical Activities - 1hb - (17.06 SQM)	Student Space (7)	
B00F - R0002 - Withdrawal Space - 1hb - (38.79 SQM)	Student Space (17)	
B00F - R0003 - Withdrawal Space - 1hb - (15.67 SQM)	Student Space (7)	
B00F - R0004 - Staff Room Annexe - (10.04 SQM)	Office (2)	
B00G - R0001 - Communal Space - (180.56 SQM)	Student Space (83)	
B00H - R0001 - Reading Area - (91.73 SQM)	Student Space (42)	
B00H - R0005 - Canteen - (13.86 SQM)	Not Applicable	Circulation or storage space.