


VENTILATION AUDIT REPORT

SCHOOL:	Yass Public School (3549)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Goulburn
LOCAL GOVERNMENT AREA:	Yass Valley

3549 - Yass Public School
Site Plan (11477)



1:1,024

Printed: 23-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (80.34 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0007 - Home Base - (80.47 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0002 - Staff Room Annexe - (9.33 SQM)	● Office (2)	
B00B - R0005 - Movement - (10.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - M - (46.19 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0012 - Staff Room Annexe - (7.44 SQM)	● Office (1)	
B00B - R0013 - Home Base - M - (46.4 SQM) - Teaching Space: 1	● Student Space (21)	
B00B - R0014 - Practical Activities - M - 1hb - (23.35 SQM)	● Student Space (10)	
B00C - R0001 - Home Base - (51.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0002 - Home Base - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0006 - Practical Activities/Movement - 2hb - (28.01 SQM)	● Student Space (12)	
B00E - R0001 - Home Base - (58.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0002 - Withdrawal Space - 1hb - (15.95 SQM)	● Student Space (7)	
B00E - R0003 - Home Base - (45.82 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0004 - Home Base - (58.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0002 - Reading Area - (25.87 SQM)	● Student Space (12)	
B00F - R0003 - Home Base - (57.34 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0004 - Home Base - (45.15 SQM) - Teaching Space: 1	● Student Space (20)	
B00F - R0005 - Withdrawal Space - 1hb - (8.9 SQM)	● Student Space (4)	
B00G - R0001 - Practical Activities - 1hb - (21.07 SQM)	● Student Space (9)	
B00G - R0002 - Home Base - (33.92 SQM) - Teaching Space: 1	● Student Space (15)	
B00G - R0003 - Special Programs Room - (28.57 SQM)	● Student Space (13)	
B00G - R0004 - Practical Activities - 1hb - (20.67 SQM)	● Student Space (9)	
B00G - R0005 - Movement - (14.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (30.76 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0010 - Withdrawal Space - 1hb - (13.02 SQM)	● Student Space (6)	
B00G - R0015 - Reading Area - (90.97 SQM)	● Student Space (42)	
B00G - R0023 - Principal - (15.08 SQM)	● Office (3)	
B00G - R0025 - Sick Bay - (9.3 SQM)	● Student Space (4)	
B00G - R0031 - Home Base/Practical Activities - (59.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0032 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Movement - (12.28 SQM)	Not Applicable	Circulation or storage space.
B00P - R0011 - Deputy Principal - (11.69 SQM)	● Office (2)	
B00P - R0012 - Staff Kitchen - (13.27 SQM)	● Office (3)	
B00P - R0013 - Staff Room - (24.06 SQM)	● Office (6)	
B00P - R0014 - Staff Room Annexe - (16.66 SQM)	● Office (4)	
B00P - R0015 - Interview - (20.38 SQM)	● Office (5)	
B00P - R0016 - Movement - (15.77 SQM)	Not Applicable	Circulation or storage space.
B00P - R0017 - Principal - (20.46 SQM)	● Office (5)	
B00P - R0018 - Clerical Office - (22.06 SQM)	● Office (5)	
B00Q - R0001 - Communal Space - (144.35 SQM)	● Student Space (66)	
B00Q - R0002 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0003 - Raised Platform - (60.71 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0005 - Movement - (13.2 SQM)	Not Applicable	Circulation or storage space.
OS 602 11017 - OS 602 11017 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	