

VENTILATION AUDIT REPORT

SCHOOL:	Yawarra Community School (5769)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

5769 - Yawarra Community School
Site Plan (12976)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0001 - Hydrotherapy - Pool - (204.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Entry Vestibule - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (16.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Clerical/Printing - (11.58 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Entry Vestibule - (11.05 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Clerical Office - (11.49 SQM)	Office (2)	
B00I - R0003 - Principal - (11.22 SQM)	Office (2)	
B00I - R0006 - Study Annexe - (15.47 SQM)	Office (3)	
B00I - R0007 - Staff Room - (43.92 SQM)	Office (10)	
B00I - R0010 - Sick Bay - (11.1 SQM)	Student Space (5)	
B00I - R0011 - Interview - (11.64 SQM)	Office (2)	
B00I - R0013 - Duplicating Workroom - (12.62 SQM)	Office (3)	
B00I - R0014 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Study Annexe - (57.74 SQM)	Office (14)	
B00K - R0004 - Entry Vestibule - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Study Annexe - (57.74 SQM)	Office (14)	
B00L - R0001 - Withdrawal - M - (9.6 SQM)	Student Space (4)	
B00L - R0005 - Home Base/Practical Activities - M - (86.39 SQM) - Teaching Space: 1	Student Space (40)	
B00L - R0008 - Home Base/Practical Activities - M - (72.93 SQM) - Teaching Space: 1	Student Space (33)	
B00L - R0009 - Withdrawal - M - (8.51 SQM)	Student Space (3)	
B00L - R0010 - Clerical Office - (7.97 SQM)	Office (1)	
B00L - R0012 - Clerical Office - (43.22 SQM)	Office (10)	
B00L - R0013 - Clerical Office - (10.57 SQM)	Office (2)	
B00L - R0014 - Clerical Office - (9.35 SQM)	Office (2)	
B00M - R0001 - Interview - (11.49 SQM)	Office (2)	
B00M - R0002 - Entry Vestibule - (11.43 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Clerical Office/Workroom - (32.34 SQM)	Office (8)	
B00M - R0006 - Withdrawal - M - (29.19 SQM)	Student Space (13)	
B00M - R0007 - Clerical Office - (10.45 SQM)	Office (2)	
B00M - R0008 - Principal - (10.21 SQM)	Office (2)	
B00M - R0009 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Clerical Office/Workroom - (58.74 SQM)	Office (14)	
B00N - R0004 - Entry Vestibule - (14.65 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Seminar - Type 3 - (15.39 SQM)	Office (3)	
B00N - R0009 - Interview - (12.08 SQM)	Office (3)	
B00N - R0010 - Interview - (12.18 SQM)	Office (3)	
B00N - R0011 - Reading Area - (39.67 SQM)	Student Space (18)	
B00O - R0002 - Entry Vestibule - (13.9 SQM)	Not Applicable	Circulation or storage space.
B00O - R0003 - Special Programs Room - (114.33 SQM)	Student Space (53)	
B00O - R0004 - Staff Kitchen - (16.9 SQM)	Office (4)	
B00S - R0001 - Home Base - M - (90.49 SQM) - Teaching Space: 1	Student Space (41)	
B0JJ - R0001 - Reading Area - (77.41 SQM)	Student Space (35)	
B0JJ - R0002 - Reading Area - (76.88 SQM)	Student Space (35)	
B0JJ - R0007 - Seminar/Study - (9.51 SQM)	Office (2)	
B0JJ - R0008 - Outdoor Learning Area - (21.36 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R0012 - Outdoor Learning Area - (21.55 SQM)	Not Applicable	Circulation or storage space.
B0JJ - R0013 - Seminar/Study - (9.34 SQM)	Office (2)	