

VENTILATION AUDIT REPORT

SCHOOL:	Yenda Public School (3554)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Griffith

3554 - Yenda Public School
Site Plan (11479)



1:1,060

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0001 - Canteen - (21.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practical Activities - (27.48 SQM)	● Student Space (12)	
B00D - R0001 - Entry Vestibule - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Clerical Office/Workroom - (27.83 SQM)	● Office (6)	
B00D - R0003 - Staff Kitchen - (7.67 SQM)	● Office (1)	
B00D - R0004 - Staff Room - (35.66 SQM)	● Office (8)	
B00D - R0007 - Principal - (17.44 SQM)	● Office (4)	
B00D - R0010 - Home Base - (60.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0011 - Practical Activities/Movement - 1hb - (18.77 SQM)	● Student Space (8)	
B00D - R0012 - Withdrawal Space - 2hb - (11.84 SQM)	● Student Space (5)	
B00D - R0013 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0014 - Practical Activities/Movement - 1hb - (18.75 SQM)	● Student Space (8)	
B00D - R0016 - Movement - (32.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Deputy Principal - (12.84 SQM)	● Office (3)	
B00D - R0020 - Sick Bay - (8.65 SQM)	● Student Space (4)	
B00D - R0022 - Special Programs Room - (12.82 SQM)	● Student Space (5)	
B00D - R0024 - Movement - (147.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (14.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (152.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Movement - (14.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Reading Area - (88.84 SQM)	● Student Space (41)	
B00E - R0012 - Home Base - (60.74 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0013 - Practical Activities/Movement - 1hb - (18.7 SQM)	● Student Space (8)	
B00E - R0015 - Withdrawal Space - 2hb - (11.9 SQM)	● Student Space (5)	
B00E - R0016 - Home Base - (60.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0017 - Practical Activities/Movement - 1hb - (18.8 SQM)	● Student Space (8)	
B00G - R0001 - Communal Space - (145.29 SQM)	● Student Space (67)	
B00G - R0002 - Raised Platform - (60.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Movement - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
OS 601 15259 - OS 601 15259 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	