


VENTILATION AUDIT REPORT

SCHOOL:	Yetman Public School (3559)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Inverell

3559 - Yetman Public School
Site Plan (11481)










1:702

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (44.4 SQM)	 Student Space (20)	
B00B - R0002 - Reading Area - (53.29 SQM)	 Student Space (24)	
B00B - R0003 - Home Base - (53.43 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0005 - Principal - (11.09 SQM)	 Office (2)	
B00B - R0006 - Clerical Office - (6.61 SQM)	 Office (1)	
B00C - R0002 - Home Base - (56.95 SQM) - Teaching Space: 1	 Student Space (26)	
B00C - R0005 - Staff Room - (15.03 SQM)	 Office (3)	
B00D - R0001 - Canteen - (8.91 SQM)	Not Applicable	Circulation or storage space.