

VENTILATION AUDIT REPORT

SCHOOL:	York Public School (4482)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

4482 - York Public School
Site Plan (11420)



1:1,759

Printed: 31-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Practical Activities - 1hb - (18.2 SQM)	● Student Space (8)	
B001 - R0002 - Home Base - (50.41 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0003 - Movement - (42.47 SQM)	Not Applicable	Circulation or storage space.
B001 - R0004 - Home Base - (50.41 SQM) - Teaching Space: 1	● Student Space (23)	
B001 - R0006 - Practical Activity Area - (11.46 SQM)	● Student Space (5)	
B002 - R0001 - Movement - (65.85 SQM)	Not Applicable	Circulation or storage space.
B002 - R0006 - Practical Activities - 1hb - (10.09 SQM)	● Student Space (4)	
B002 - R0007 - Home Base - (74.98 SQM) - Teaching Space: 1	● Student Space (34)	
B003 - R0001 - Movement - (45.48 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Practical Activities - 1hb - (20.21 SQM)	● Student Space (9)	
B003 - R0005 - Home Base - (77.55 SQM) - Teaching Space: 1	● Student Space (35)	
B003 - R0006 - Home Base - (77.22 SQM) - Teaching Space: 1	● Student Space (35)	
B003 - R0008 - Practical Activities - 1hb - (21.41 SQM)	● Student Space (9)	
B004 - R0001 - Movement - (42.87 SQM)	Not Applicable	Circulation or storage space.
B004 - R0002 - Practical Activities - 1hb - (18.41 SQM)	● Student Space (8)	
B004 - R0003 - Home Base - (50.39 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0004 - Home Base - (51.39 SQM) - Teaching Space: 1	● Student Space (23)	
B004 - R0005 - Practical Activities - 1hb - (18.27 SQM)	● Student Space (8)	
B005 - R0001 - Movement - (76.08 SQM)	Not Applicable	Circulation or storage space.
B005 - R0002 - Practical Activities - 1hb - (18.42 SQM)	● Student Space (8)	
B005 - R0003 - Home Base - (51.13 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0004 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B005 - R0005 - Practical Activities - 1hb - (18.42 SQM)	● Student Space (8)	
B005 - R0007 - Staff Room Annexe - (9.16 SQM)	● Office (2)	
B006 - R0001 - Principal - (18.89 SQM)	● Office (4)	
B006 - R0002 - Clerical Office/Workroom - (12.57 SQM)	● Office (3)	
B006 - R0003 - Movement - (28.39 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Duplicating Workroom - (16.54 SQM)	● Office (4)	
B006 - R0005 - Sick Bay - (8.24 SQM)	● Student Space (3)	
B006 - R0010 - Deputy Principal - (12.97 SQM)	● Office (3)	
B006 - R0014 - Clerical Office - (14.15 SQM)	● Office (3)	
B006 - R0015 - Entry Vestibule - (14.08 SQM)	Not Applicable	Circulation or storage space.
B006 - R1005 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B006 - R1016 - Reading Area - (106.81 SQM)	● Student Space (49)	
B006 - R1017 - Seminar/Study - (11.64 SQM)	● Office (2)	
B006 - R1018 - Seminar/Study - (12.12 SQM)	● Office (3)	
B006 - R1019 - Staff Room - (58.2 SQM)	● Office (14)	
B006 - R1020 - Staff Kitchen - (16.24 SQM)	● Office (4)	
B006 - R1022 - Home Base - (90.76 SQM) - Teaching Space: 1	● Student Space (42)	
B008 - R0001 - Movement - (75.29 SQM)	Not Applicable	Circulation or storage space.
B008 - R0004 - Interview - (16.52 SQM)	● Office (4)	
B008 - R0006 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
B008 - R0007 - Practical Activities - 1hb - (14.06 SQM)	● Student Space (6)	
B008 - R0008 - Home Base - (55.32 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R0009 - Home Base - (50.8 SQM) - Teaching Space: 1	● Student Space (23)	
B008 - R0010 - Practical Activities - 1hb - (18.37 SQM)	● Student Space (8)	
B008 - R1001 - Movement - (60.42 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B008 - R1004 - Staff Room Annexe - (17.22 SQM)	Office (4)	
B008 - R1005 - Movement - (5.29 SQM)	Not Applicable	Circulation or storage space.
B008 - R1006 - Practical Activities - 1hb - (13.62 SQM)	Student Space (6)	
B008 - R1007 - Home Base - (55.73 SQM) - Teaching Space: 1	Student Space (25)	
B008 - R1008 - Home Base - (50.76 SQM) - Teaching Space: 1	Student Space (23)	
B008 - R1009 - Practical Activities - 1hb - (18.14 SQM)	Student Space (8)	
B00A - R0001 - Movement - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (51.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Practical Activities - 1hb - (33.63 SQM)	Student Space (15)	
B00A - R0014 - Home Base - (61.35 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0015 - Withdrawal Space - 1hb - (12.33 SQM)	Student Space (5)	
B00A - R0016 - Movement - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Home Base - (59.87 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0018 - Interview - (11.86 SQM)	Office (2)	
B00B - R0001 - Movement - (58.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (6.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Withdrawal Space - 1hb - (5.87 SQM)	Student Space (2)	
B00B - R0008 - Home Base - (61.13 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0009 - Movement - (17.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Practical Activities - 1hb - (19.46 SQM)	Student Space (9)	
B00B - R0013 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0014 - Movement - (12.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Withdrawal Space - 1hb - (11.95 SQM)	Student Space (5)	
B00B - R0016 - Movement - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Home Base - (60.87 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0020 - Practical Activities - 1hb - (40.67 SQM)	Student Space (18)	
B00B - R1001 - Movement - (64.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Withdrawal Space - 1hb - (5.75 SQM)	Student Space (2)	
B00B - R1005 - Special Programs Room - (62.36 SQM)	Student Space (28)	
B00B - R1006 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Practical Activities - 1hb - (19.85 SQM)	Student Space (9)	
B00B - R1011 - Home Base - (61.02 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1012 - Movement - (13.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Withdrawal Space - 1hb - (12.21 SQM)	Student Space (5)	
B00B - R1014 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1018 - Practical Activities - 1hb - (40.76 SQM)	Student Space (18)	
B00E - R0001 - Communal Space - (146.85 SQM)	Student Space (68)	
B00E - R0002 - Raised Platform - (58.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (11.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Canteen - (25.75 SQM)	Not Applicable	Circulation or storage space.
OS 602 10132 - OS 602 10132 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13493 - OS 602 13493 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15791 - OS 602 15791 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 12134 - OS 603 12134 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 14243 - OS 603 14243 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	

