

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Young High School (8155)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hilltops</b>

8155 - Young High School  
Site Plan (11896)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Computer Room - (75.41 SQM)	Student Space (34)	
B00D - R0011 - Computer Room - (66.81 SQM)	Student Space (30)	
B00D - R1012 - Design L.S. - (93.67 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R1013 - Leading Teacher - (20.67 SQM)	Office (5)	
B00D - R1014 - Commonroom - (91.86 SQM)	Office (22)	
B0AA - M0005 - Interview/Meeting - (61.55 SQM)	Office (15)	
B0AA - R0001 - General Assistants - (16.41 SQM)	Office (4)	
B0AA - R0003 - Practice/Seminar - (16.29 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0005 - Music Learning Space - (33.5 SQM) - Teaching Space: 1	Student Space (15)	
B0AA - R0006 - Practice/Seminar - (33.42 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0007 - Movement - (57.08 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0008 - Stage - (64.79 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0009 - Multi-Purpose Space - (197.08 SQM)	Student Space (91)	
B0AA - R0010 - Public Entry - (65.94 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0011 - Movement - (52.87 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0016 - Administration - Clerical - (33.27 SQM)	Office (8)	
B0AA - R0017 - Principal Office - (33.55 SQM)	Office (8)	
B0AA - R0020 - Deputy Principal Office - (19.94 SQM)	Office (4)	
B0AA - R0021 - Administration - Clerical - (33.55 SQM)	Office (8)	
B0AA - R0028 - Movement - (46.52 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0031 - Clinic - (18.22 SQM)	Office (4)	
B0AA - R0032 - Movement - (46.66 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0034 - Music Learning Space - (49.52 SQM) - Teaching Space: 1	Student Space (22)	
BOBB - R0004 - Movement - (19.38 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0011 - Movement - (58.24 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0014 - Student Canteen - (54.22 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0018 - Movement - (69.47 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1003 - Workshop Area - (51.61 SQM)	Student Space (23)	
BOBB - R1005 - Art Learning Space - (55.87 SQM) - Teaching Space: 1	Student Space (25)	
BOBB - R1009 - Darkroom Space - (27.28 SQM)	Office (6)	
BOBB - R1011 - Art Learning Space - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
BOBB - R1012 - Staff Study - (19.62 SQM)	Office (4)	
BOBB - R1016 - Movement - (72.95 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1017 - Art Learning Space - (64.13 SQM) - Teaching Space: 1	Student Space (29)	
BOCC - R0001 - Food/Research Space - (16.59 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0002 - Food Technology L.S. - (93.58 SQM) - Teaching Space: 1	Student Space (43)	
BOCC - R0003 - Staff Study - (24.56 SQM)	Office (6)	
BOCC - R0004 - Design L.S. - (88.46 SQM) - Teaching Space: 1	Student Space (41)	
BOCC - R0006 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0009 - Food Technology L.S. - (95.59 SQM) - Teaching Space: 1	Student Space (44)	
BOCC - R0017 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0019 - Movement - (51.73 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0001 - Design L.S. - (56.33 SQM) - Teaching Space: 1	Student Space (26)	
B0DD - R0003 - Materials Technology L.S. - (88.82 SQM) - Teaching Space: 1	Student Space (41)	
B0DD - R0004 - Welding/Hot Metals Area - (9.08 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0005 - Metal Technology Bay - (35.96 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0007 - Movement - (152.24 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0009 - Welding/Hot Metals Area - (11.52 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0011 - Materials Technology L.S. - (91.69 SQM) - Teaching Space: 1	Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BODD - R0012 - Wood Technology Bay - (37.45 SQM)	Not Applicable	Circulation or storage space.
BODD - R0014 - Materials Technology L.S. - (97.91 SQM) - Teaching Space: 1	Student Space (45)	
BODD - R0017 - Staff Study - (31.48 SQM)	Office (7)	
BODD - R0021 - Movement - (11.56 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0001 - Interview/Office - Type 1 - (14.44 SQM)	Office (3)	
BOEE - R0002 - Seminar - (14.41 SQM)	Office (3)	
BOEE - R0003 - Senior Study - (46.85 SQM)	Office (11)	
BOEE - R0004 - Movement - (18.9 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0005 - Entry - (18.56 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0007 - Duplicating Workroom - (19.98 SQM)	Office (4)	
BOEE - R0008 - Workroom - (36.22 SQM)	Office (9)	
BOEE - R0009 - Seminar - (48.34 SQM)	Office (12)	
BOEE - R0010 - Main Area - (278.37 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0011 - Seminar - (12.38 SQM)	Office (3)	
BOEE - R0015 - Movement - (13.17 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0016 - Seminar - Type 2 - (25.34 SQM)	Office (6)	
BOHH - R0001 - Movement - (27.69 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0004 - Growing/Breeding - (12.57 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0001 - Staff Study - (28.77 SQM)	Office (7)	
BGFS - R0006 - Laboratory L.S. - (86.76 SQM) - Teaching Space: 1	Student Space (40)	
BGFS - R0007 - Growing/Breeding - (8.6 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0008 - Preparation - (28.79 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0009 - Laboratory L.S. - (86.88 SQM) - Teaching Space: 1	Student Space (40)	
BGFS - R0014 - Laboratory L.S. - (88 SQM) - Teaching Space: 1	Student Space (40)	
BGFS - R0015 - Preparation - (25.91 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0017 - Staff Study - (52.86 SQM)	Office (13)	
BGFS - R0021 - Laboratory L.S. - (88.14 SQM) - Teaching Space: 1	Student Space (40)	
BGFS - R0022 - Preparation - (30.42 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0024 - Laboratory L.S. - (86 SQM) - Teaching Space: 1	Student Space (39)	
BGFS - R0028 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0044 - Gymnasium - (323.72 SQM)	Student Space (150)	
BGFS - R0045 - Movement - (135.06 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0047 - Movement - (14.08 SQM)	Not Applicable	Circulation or storage space.
BGFS - R0050 - Movement - (166.45 SQM)	Not Applicable	Circulation or storage space.
BGFS - R1004 - General Learning Space - (65.89 SQM) - Teaching Space: 1	Student Space (30)	
BGFS - R1005 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1006 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1007 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1008 - Staff Study - (26.72 SQM)	Office (6)	
BGFS - R1009 - Staff Study - (13.07 SQM)	Office (3)	
BGFS - R1012 - General Learning Space - (60.68 SQM) - Teaching Space: 1	Student Space (28)	
BGFS - R1013 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1014 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1015 - Staff Study - (32.49 SQM)	Office (8)	
BGFS - R1018 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1021 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
BGFS - R1022 - General Learning Space - (60.68 SQM) - Teaching Space: 1	Student Space (28)	
BGFS - R1026 - Preparation - (17.2 SQM)	Not Applicable	Circulation or storage space.
BGFS - R1027 - Special Learning Space - (62 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BGFS - R1028 - Special Learning Space - (53.96 SQM) - Teaching Space: 1	● Student Space (25)	
BGFS - R1029 - Staff Study - (27.82 SQM)	● Office (6)	
BGFS - R1032 - Interview/Office - Type 1 - (16.74 SQM)	● Office (4)	
BGFS - R1044 - Movement - (268 SQM)	Not Applicable	Circulation or storage space.
BGFS - R2007 - General Learning Space - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2008 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2011 - Staff Study - (53.15 SQM)	● Office (13)	
BGFS - R2012 - Interview/Office - Type 1 - (13.57 SQM)	● Office (3)	
BGFS - R2015 - General Learning Space - (60.76 SQM) - Teaching Space: 1	● Student Space (28)	
BGFS - R2016 - General Learning Space - (53.29 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2017 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2021 - Movement - (6.19 SQM)	Not Applicable	Circulation or storage space.
BGFS - R2023 - Seminar - Type 1 - (25.95 SQM)	● Office (6)	
BGFS - R2024 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2025 - General Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2026 - Computer Learning Space - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
BGFS - R2032 - Computer Learning Space - (52.57 SQM) - Teaching Space: 1	● Student Space (24)	
BGFS - R2035 - Computer Learning Space - (55.78 SQM) - Teaching Space: 1	● Student Space (25)	
BGFS - R2039 - Commonroom - (39.75 SQM)	● Office (9)	
BGFS - R2040 - Performance Workspace - (83.08 SQM) - Teaching Space: 1	● Student Space (38)	
BGFS - R2042 - Movement - (280.74 SQM)	Not Applicable	Circulation or storage space.
OS 502 13751 - OS 502 13751 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 801 18021 - OS 801 18021 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.