

VENTILATION AUDIT REPORT

SCHOOL:	Young North Public School (4131)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Hilltops

4131 - Young North Public School
Site Plan (11421)





1:1,255

Printed: 15-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Room - (56.81 SQM)	Office (14)	
B00A - R0005 - Principal - (20.94 SQM)	Office (5)	
B00A - R0008 - Entry Vestibule - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (16.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office/Workroom - (27.11 SQM)	Office (6)	
B00A - R0011 - Staff Room Annexe - (8.17 SQM)	Office (2)	
B00A - R0012 - Sick Bay - (7.25 SQM)	Student Space (3)	
B00A - R0016 - Duplicating Workroom - (11.78 SQM)	Office (2)	
B00B - R0010 - Movement - (74.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Home Base - (75.95 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0017 - Home Base - (64.43 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0018 - Withdrawal Space - 2hb - (26.91 SQM)	Student Space (12)	
B00B - R0019 - Staff Room Annexe - (12.93 SQM)	Office (3)	
B00B - R0020 - Staff Room Annexe - (12.92 SQM)	Office (3)	
B00B - R0021 - Home Base - (75.95 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0004 - Canteen - (19.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0004 - Practical Activities - 1hb - (21.16 SQM)	Student Space (9)	
B00D - R0005 - Practical Activities - 1hb - (21.24 SQM)	Student Space (9)	
B00D - R0006 - Home Base - (51.68 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0001 - Reading Area - (157.81 SQM)	Student Space (73)	
B00E - R0006 - Special Programs Room - (44.24 SQM)	Student Space (20)	
B00F - R0006 - Home Base - (66.47 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0007 - Staff Room Annexe - (26.76 SQM)	Office (6)	
B00F - R0010 - Home Base - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0011 - Home Base - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0012 - Home Base - (56.44 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0013 - Practical Activities - 1hb - (15.13 SQM)	Student Space (7)	
B00F - R0014 - Movement - (27.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (35.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (46.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Staff Room - (26.72 SQM)	Office (6)	
B00F - R0023 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0024 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0026 - Withdrawal Space - 1hb - (10.79 SQM)	Student Space (5)	
B00F - R0027 - Withdrawal Space - 1hb - (8.53 SQM)	Student Space (3)	
B00G - R0003 - Communal Space - (685.71 SQM)	Student Space (318)	
B00G - R0004 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Raised Platform - (134.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Canteen - (11.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R9004 - Movement - (44.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Practical Activities - 1hb - (21.61 SQM)	Student Space (10)	
B00H - R0004 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0005 - Withdrawal Space - 2hb - (10.84 SQM)	Student Space (5)	
B00H - R0006 - Home Base - (63.45 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0008 - Practical Activities - 1hb - (21.61 SQM)	Student Space (10)	
OS 606 15696 - OS 606 15696 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 16079 - OS 606 16079 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19283 - OS 606 19283 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 970 15529 - OS 970 15529 - Store - Single Module - (19 SQM)	Not Applicable	Circulation or storage space.