

VENTILATION AUDIT REPORT

SCHOOL:	Young Public School (3563)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Hilltops

3563 - Young Public School
Site Plan (11904)































1:1,208

Printed: 28-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (15.75 SQM)	 Office (3)	
B00A - R0002 - Staff Room Annexe - (13.2 SQM)	 Office (3)	
B00A - R0004 - Staff Room Annexe - (12.57 SQM)	 Office (3)	
B00A - R0005 - Duplicating Workroom - (13.2 SQM)	 Office (3)	
B00A - R0008 - Staff Room Annexe - (13.33 SQM)	 Office (3)	
B00A - R0009 - Sick Bay - (10.6 SQM)	 Student Space (4)	
B00A - R0010 - Movement - (10.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Entry Vestibule - (35.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (28.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (13.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Staff Room - (73.66 SQM)	 Office (18)	
B00A - R0019 - Principal - (13.1 SQM)	 Office (3)	
B00A - R0021 - Clerical Office - (13.31 SQM)	 Office (3)	
B00A - R0022 - Clerical Office/Workroom - (20.45 SQM)	 Office (5)	
B00A - R0023 - Movement - (21.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Staff Room Annexe - (11.49 SQM)	 Office (2)	
B00A - R1007 - Seminar/Study - (11.19 SQM)	 Office (2)	
B00A - R1008 - Seminar/Study - (10.77 SQM)	 Office (2)	
B00A - R1009 - Reading Area - (209.97 SQM)	 Student Space (97)	
B00A - R1010 - Movement - (14.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Movement - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (51.32 SQM) - Teaching Space: 1	 Student Space (23)	
B00B - R0002 - Practical Activities - 1hb - (18.41 SQM)	 Student Space (8)	
B00B - R0003 - Movement - (18.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (34.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Communal Space - (174.42 SQM)	 Student Space (80)	
B00C - R0002 - Raised Platform - (55.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Canteen - (26.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (84.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (58.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (10.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (15.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (51.74 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0009 - Practical Activities - 1hb - (17.89 SQM)	 Student Space (8)	
B00D - R0011 - Movement - (24.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - M - (51.79 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R0013 - Practical Activities - M - 1hb - (18.02 SQM)	 Student Space (8)	
B00D - R1001 - Movement - (27.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Home Base - (51.85 SQM) - Teaching Space: 1	 Student Space (24)	
B00D - R1004 - Practical Activities - 1hb - (18.22 SQM)	 Student Space (8)	
B00D - R1010 - Movement - (22.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Special Programs Room - (70.2 SQM)	 Student Space (32)	
B00E - R0001 - Home Base - (51.93 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R0002 - Practical Activities - 1hb - (18.11 SQM)	 Student Space (8)	
B00E - R0003 - Home Base - (56.47 SQM) - Teaching Space: 1	 Student Space (26)	
B00E - R0004 - Practical Activities - 1hb - (10.8 SQM)	 Student Space (5)	
B00E - R0006 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0013 - Home Base - (50.7 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0014 - Practical Activities - 1hb - (18.32 SQM)	Student Space (8)	
B00E - R0015 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Home Base - (51.71 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1002 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00E - R1003 - Home Base - (56.4 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1004 - Practical Activities - 1hb - (11 SQM)	Student Space (5)	
B00E - R1006 - Movement - (10.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R1009 - Movement - (20.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Withdrawal Space - 1hb - (14.49 SQM)	Student Space (6)	
B00E - R1015 - Home Base - (50.23 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1016 - Practical Activities - 1hb - (18.33 SQM)	Student Space (8)	
B00F - R0013 - Movement - (62.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Home Base/Practical Activities - M - (94.25 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0024 - Home Base/Practical Activities - M - (70.53 SQM) - Teaching Space: 1	Student Space (32)	
B00F - R0025 - Home Base - M - (93.49 SQM) - Teaching Space: 1	Student Space (43)	
B00G - R0001 - Home Base - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0002 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00G - R0003 - Practical Activities - 1hb - (18.38 SQM)	Student Space (8)	
B00G - R0004 - Home Base - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0006 - Movement - (12.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Practical Activities - 1hb - (18.38 SQM)	Student Space (8)	
B00G - R0012 - Home Base - (51.67 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0013 - Movement - (60.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (176.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 2hb - (18.93 SQM)	Student Space (8)	
B00I - R0002 - Home Base - (62.09 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0004 - Home Base - (62.3 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0006 - Practical Activities - (19.26 SQM)	Student Space (8)	
B00I - R0007 - Withdrawal Space - 2hb - (12.46 SQM)	Student Space (5)	
B00I - R0008 - Practical Activities - (29.56 SQM)	Student Space (13)	
B00I - R0009 - Home Base - (49.57 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R0011 - Withdrawal Space - 1hb - (8.08 SQM)	Student Space (3)	
B00I - R0012 - Staff Room - (30.94 SQM)	Office (7)	
B00I - R1001 - Practical Activities - (19.78 SQM)	Student Space (9)	
B00I - R1002 - Home Base - (63.3 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R1004 - Home Base - (62.83 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R1006 - Practical Activities - (19.61 SQM)	Student Space (9)	
B00I - R1007 - Withdrawal Space - 2hb - (12.48 SQM)	Student Space (5)	
B00I - R1008 - Practical Activities - (20.74 SQM)	Student Space (9)	
B00I - R1009 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R1011 - Withdrawal Space - 1hb - (8.23 SQM)	Student Space (3)	
OS 602 12475 - OS 602 12475 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	