

VENTILATION AUDIT REPORT

SCHOOL:	Young Regional School of Music (799)
AMU REGION:	Southern NSW
STATE ELECTORATE:	
LOCAL GOVERNMENT AREA:	

Siteplan

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practice/Seminar - (15.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Practice/Seminar - (15.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Practice/Seminar - (15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Practice/Seminar - (13.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Music Learning Space - (77.57 SQM)	● Student Space (35)	
B00A - R0008 - Clerical Office - (18.41 SQM)	● Office (4)	
B00A - R0009 - Commonroom - (15.01 SQM)	● Office (3)	
B00A - R0010 - Clinic - (9.41 SQM)	● Office (2)	
B00A - R0012 - Movement - (5.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (9.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Practice/Seminar - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Practice/Seminar - (14.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Practice/Seminar - (14.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practice/Seminar - (22.01 SQM)	Not Applicable	Circulation or storage space.