

# Buxton Public School

## Works notification | 14 October 2024

Dear parents, carers and staff,

During a routine inspection of Buxton Public School on 26 September 2024, mould was found in the Out of School Hours Care (OSHC) room.

Access was restricted and the care service was temporarily relocated to another room for the remainder of Term 3 (26 and 27 September).

Contractors determined the cause was a leaking toilet cistern, located inside the wall of an adjacent bathroom.

Part of the wall and carpet in the OSHC room was also damaged.

Mould remediation, replacement of carpet and repairs to the leak and wall were completed during the Spring School Holidays.

Safety measures, including air monitoring, were in place while work was done.

All inspections and remediation works were conducted in accordance with recommendations from the independent hygienist.

The room was inspected by an independent hygienist to confirm it has been fully remediated and a clearance certificate was issued – ahead of reopening today (Day 1, Term 4).

The health, safety and wellbeing of the school and the local community is our highest priority.

If you have any questions about this work, please contact the NSW Department of Education on the details below.

Thank you for your cooperation during this important work.



Email: [schoolinfrastructure@det.nsw.edu.au](mailto:schoolinfrastructure@det.nsw.edu.au)  
Phone: 1300 482 651  
[www.schoolinfrastructure.nsw.gov.au](http://www.schoolinfrastructure.nsw.gov.au)

