

St Peters Public School

Works notification | 20 February 2026

Dear staff, parents and carers,

On Friday 13 February 2026, a fragment of material suspected to contain asbestos was identified near the south-west boundary fence between Church Street and St Peters Public School.

An independent hygienist was engaged to collect the fragment for testing, undertake air monitoring and advise on remediation. Testing has confirmed that the fragment contained bonded asbestos.

NSW Health explains that 'living or working with asbestos, or just being around it, is a low risk to your health as long as the asbestos is in good condition and not damaged'.

Work to clear the soil took place the same day. The area was inspected by an independent hygienist and a clearance certificate was issued.

This location is not in an area identified on the School Asbestos Management Plan (SAMP). The register will be updated to include this recent find.

All asbestos-related work was done in accordance with work health and safety laws and the NSW Department of Education's Asbestos Management Plan. All work was completed by licensed asbestos contractors.

The health, safety, and wellbeing of the school and the local community are our highest priority.

Thank you for your cooperation during this important work.



Email: schoolinfrastructure@det.nsw.edu.au
Phone: 1300 482 651
schoolinfrastructure.nsw.gov.au