

Lethbridge Park Public School

Works notification | 21 March 2025

Dear staff, parents and carers,

We would like to inform you about a disruption to preschool operations at Lethbridge Park Public School on Thursday 20 March 2025.

Preschool students and staff in Building H were relocated to the library between 12:10 pm and 2 pm in response to a report of electrical sparks coming from the roof solar panels.

Fire and Rescue NSW attended the school and disconnected the main power supply to the building.

A licensed electrician was engaged to inspect the building. The electrician isolated power from the solar panels to the inverter, and from the inverter to the building. Solar panel inverters ensure that the energy generated by solar panels can be safely used.

Power to and from the inverter will remain isolated until a replacement inverter is organised.

Power to Building H was restored and the school received clearance from the electrician that students and staff could return to the building.

The health, safety, and wellbeing of the school and local community is our highest priority.

Thank you for your cooperation during this important work.



Email: schoolinfrastructure@det.nsw.edu.au
Phone: 1300 482 651
www.schoolinfrastructure.nsw.gov.au