

# Henry Kendall High School

## Works notification | 30 April 2025

Dear staff, parents, and carers,

A small fire was detected above a ceiling-mounted gas heater in the hall at Henry Kendall High School on Friday 11 April 2025.

The cause was an obstruction above the heater.

Access to the hall was restricted and all heaters were immediately turned off.

Wall mounted fans were turned on and all doors opened to improve ventilation from any potential residual smoke or fumes.

The closure did not affect school operations.

The heater was cleared of any obstructions and all hall heaters were checked by a qualified and licensed gas repair professional later the same day.

No further heater obstructions or gas leaks were identified.

The hall was cleared to be reopened for use.

The health, safety and wellbeing of all members of our school and the local community are our highest priorities.

If you have any questions about this work, please contact the NSW Department of Education on the details below.

Thank you for your cooperation during this important work.



Email: [schoolinfrastructure@det.nsw.edu.au](mailto:schoolinfrastructure@det.nsw.edu.au)  
Phone: 1300 482 651  
[schoolinfrastructure.nsw.gov.au](https://schoolinfrastructure.nsw.gov.au)

