

Koorinal High School

Works notification | 3 March 2026

Dear parents, staff and carers,

On Monday 16 February 2026 at Koorinal High School, a contractor identified that a girls toilet partition had been shaved/sanded back in Building EL. The partition was listed on the School Asbestos Management Plan (SAMP) as containing bonded asbestos. Testing has since confirmed that the partition does not contain asbestos.

The contractor encapsulated the area with PVA spray, which is similar to a glue, on Wednesday 18 February 2026. The individual toilet was immediately closed and locked to students and staff.

An Independent hygienist attended the school site on Tuesday 24 February 2026 to inspect the area, collect samples for testing and conduct air monitoring.

On Wednesday 25 February 2026, air monitoring results came back and showed that there was not a detectable level of asbestos fibres in the air in this area. As a result, the area was reopened the same day.

On Friday 27 February 2026, testing results of the suspected partition listed on the SAMP were negative for asbestos. The SAMP will be updated accordingly regarding the recent results.

Thank you for your cooperation during this important work.



Email: schoolinfrastructure@det.nsw.edu.au
Phone: 1300 482 651
www.schoolinfrastructure.nsw.gov.au