


SCHOOL:	Annangrove Public School (3719)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Castle Hill
LOCAL GOVERNMENT AREA:	The Hills

3719 - Annangrove Public School
Site Plan (10855)

















1:1,565

Printed: 22-Jul-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (10.8 SQM)	 Student Space (5)	
B00A - R0004 - Raised Platform - (24.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (69.36 SQM) - Teaching Space: 1	 Student Space (116)	
B00A - R0007 - Home Base - (57.35 SQM) - Teaching Space: 1	 Student Space (116)	
B00A - R9001 - Special Programs Room - (51.56 SQM)	 Student Space (23)	
B00B - R0007 - Practical Activities - 1hb - (15.18 SQM)	 Student Space (7)	
B00B - R0009 - Home Base - (81.2 SQM) - Teaching Space: 1	 Student Space (98)	
B00B - R1006 - Practical Activities - 1hb - (20.51 SQM)	 Student Space (9)	
B00B - R1007 - Home Base - (58.22 SQM) - Teaching Space: 1	 Student Space (66)	
B00B - R1008 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Special Programs Room - (15.56 SQM)	 Student Space (7)	
B00C - R0002 - Canteen - (8.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Reading Area - (95.61 SQM)	 Student Space (44)	
OS 502 13573 - OS 502 13573 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 606 19583 - OS 606 19583 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	