


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Barnsley Public School (1138)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Lake Macquarie

1138 - Barnsley Public School
Site Plan (10171)



1:1,133

Printed: 07-Jul-2021

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (16.29 SQM)	Office (4)	
B00A - R0002 - Staff Room - (32.57 SQM)	Office (8)	
B00A - R0003 - Staff Kitchen - (16.89 SQM)	Office (4)	
B00A - R0004 - Deputy Principal - (12.78 SQM)	Office (3)	
B00A - R0006 - Sick Bay - (9.72 SQM)	Student Space (4)	
B00A - R0007 - Duplicating Workroom - (20.31 SQM)	Office (5)	
B00A - R0008 - Clerical Office/Workroom - (15.95 SQM)	Office (3)	
B00A - R0009 - Interview - (12.61 SQM)	Office (3)	
B00A - R0010 - Deputy Principal - (12.85 SQM)	Office (3)	
B00A - R0011 - Principal - (17 SQM)	Office (4)	
B00A - R0018 - Movement - (71.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (79.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00B - R0003 - Home Base - (50.41 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0004 - Practical Activities - 1hb - (22.58 SQM)	Student Space (10)	
B00B - R0007 - Practical Activities - 1hb - (23.37 SQM)	Student Space (10)	
B00B - R0008 - Home Base - (50.35 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0009 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00B - R0011 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00B - R0013 - Practical Activities - 1hb - (23.51 SQM)	Student Space (10)	
B00B - R0015 - Home Base - (50.59 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0016 - Home Base - (50.74 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R0017 - Withdrawal Space - 1hb - (5.92 SQM)	Student Space (2)	
B00B - R0019 - Practical Activities - 1hb - (22.55 SQM)	Student Space (10)	
B00B - R0023 - Movement - (125.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (163.14 SQM)	Student Space (75)	
B00C - R0005 - Movement - (71.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Special Programs Room - (32.44 SQM)	Student Space (15)	
B00E - R0003 - Practical Activities - 1hb - (20.64 SQM)	Student Space (9)	
B00E - R0004 - Home Base - (55.23 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0005 - Withdrawal Space - 1hb - (11.23 SQM)	Student Space (5)	
B00E - R0006 - Practical Activities - 1hb - (20.64 SQM)	Student Space (9)	
B00E - R0007 - Home Base - (55.24 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0012 - Practical Activities - 1hb - (20.52 SQM)	Student Space (9)	
B00E - R0013 - Home Base - (55.18 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0014 - Withdrawal Space - 1hb - (11.17 SQM)	Student Space (5)	
B00E - R0015 - Practical Activities - 1hb - (20.52 SQM)	Student Space (9)	
B00E - R0016 - Home Base - (55.18 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0024 - Movement - (63.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (91.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (54.95 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0008 - Withdrawal Space - 1hb - (10.93 SQM)	Student Space (5)	
B00F - R0009 - Home Base - (54.99 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0013 - Movement - (29.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Practical Activities - 1hb - (20.58 SQM)	Student Space (9)	
B00F - R0015 - Practical Activities - 1hb - (20.59 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Canteen - (36.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Raised Platform - (39.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Communal Space - (151.15 SQM)	● Student Space (70)	
B00I - R0002 - Practical Activities - 1hb - (19.12 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (60.26 SQM) - Teaching Space: 1	● Student Space (39)	
B00I - R0005 - Withdrawal Space - 2hb - (11.69 SQM)	● Student Space (5)	
B00I - R0006 - Practical Activities - 1hb - (18.32 SQM)	● Student Space (8)	
B00I - R0007 - Home Base - (60.26 SQM) - Teaching Space: 1	● Student Space (39)	
B00I - R0010 - Practical Activities - 1hb - (20.71 SQM)	● Student Space (9)	
B00I - R0011 - Withdrawal Space - 1hb - (9.2 SQM)	● Student Space (4)	
B00I - R0012 - Home Base - (58.22 SQM) - Teaching Space: 1	● Student Space (39)	
B00I - R0015 - Special Programs Room - (32.38 SQM)	● Student Space (15)	
OS 602 10233 - OS 602 10233 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14903 - OS 602 14903 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19906 - OS 606 19906 - Learning Unit - Standard With P.A.A A/C - (SQM)	● Student Space ()	