

SCHOOL:	Blacksmiths Public School (4197)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Lake Macquarie

4197 - Blacksmiths Public School
Site Plan (10884)



1:973

Printed: 21-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Principal - (13.67 SQM)	Office (3)	
B00A - R0005 - Staff Room - (16.31 SQM)	Office (4)	
B00A - R0006 - Duplicating Workroom - (6.09 SQM)	Office (1)	
B00A - R0007 - Clerical Office - (9.47 SQM)	Office (2)	
B00A - R0008 - Entry Vestibule - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (57.09 SQM) - Teaching Space: 1	Student Space (78)	
B00A - R0011 - Home Base - (57.23 SQM) - Teaching Space: 1	Student Space (65)	
B00A - R0014 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Reading Area - (56.92 SQM)	Student Space (26)	
B00A - R0019 - Home Base - (70.3 SQM) - Teaching Space: 1	Student Space (117)	
B00A - R0020 - Practical Activities - 1hb - (15.67 SQM)	Student Space (7)	
B00B - R0001 - Canteen - (56.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (10.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (56.52 SQM) - Teaching Space: 1	Student Space (85)	
B00D - R0001 - Outdoor Learning Area - (30.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Communal Space - (113.79 SQM)	Student Space (52)	
OS 505 16084 - OS 505 16084 - Admin Staff/Principal/Secure Store - (76 SQM)	Office (19)	